

Development of Standard Technology for In-service Test

Soon Joon Hong^a, Young Wook Chung^a, Byung Chul Lee^a, Gang Il Choo^b, Kang Deok Rhee^b, Taek Soo Youm^b,
Kyung Hoon Lee^b, Jin Ho Kim^b, Kwang Sik Choi^b, Dong Jin Lee^b, Ho Jin Jung^b, In Sam Hwang^b, Bong Baek Kim^b,
Jae Won Lee^b, and Soo Gil Lee^c

^a FNC Technology Co., Ltd., SNU RPIC #516, San 4-2 Bongchun7-dong, Gwanak-gu, Seoul 151-818, Republic of Korea
sjhong90@fnctech.com

^b Korea Hydro & Nuclear Power Co., Ltd

^c Hanvit Power Service

1. INTRODUCTION

Nuclear power plant has several safety features and each safety feature is based on the operation of pumps and valves. Thus, it is an essential basis for the safety of nuclear power plant to keep operational readiness of pumps and valves. Technology Rule 63.1.2 of Nuclear Facility etc. requires In-service Test (IST) for pumps and valves.

Our domain nuclear power plants can be classified into

- 1) Westinghouse 2 Loop (PWR600)
- 2) Westinghouse 3 Loop (PWR900)
- 3) Framatom 3 Loop
- 4) Korea Standard Nuclear Power Plant (KSNP)
- 5) CANDU

Each type of plant has similar design and maintenance features. However, the IST program in each type is slightly different each other in components subjected to IST, test item, test period and so on. These have caused excessive effort for the test itself, the response to regulatory authority, and the response to the change of code and standards.

This study is motivated in order to resolve such problems as a first step. The objectives of this study is

- 1) Development of standardization methodology of IST for each plant type
- 2) Development of IST technical backgrounds for each plant type
- 3) Development of standard IST plan on the base of the technical backgrounds for each plant type

The results of this study will be utilized in

- 1) Effective response for the regulatory activities using the standard technical backgrounds and plan for IST
- 2) Exclusion of none-safety functioned components from the definite analysis for each component
- 3) Foundations for the relief request

Because of practical status in each plant, the concerned plants are limited to: 1) KSNP (YGN3&4, YGN5&6, UCN3&4, UCN5&6), 2) PWR900 (Kori3&4, YGN1&2), 3) CANDU

2. APPROACH TO STANDARD TECHNOLOGY

2.1 Code and Standards

The first code and standard is Ministry of Science and Technology (MOST) Guide 2004-14[1]. This guide

identifies the requirement of IST, and endows KEPIC MO 2000 [2] or ASME OM 1995 and its addenda [3] for detailed test requirements. KEPIC MO 2000 is also based on ASME OM 1995 and its addenda. KINS-G-018 (Rev.1) is also used as a code and standards [4]. NUREG-1482 (Rev.1) is referred to as complementary code and standards[5].

2.2 Standardization Methodology

Standardization for each type of plants was carried out according to following procedures

- 1) List up the components subjected to technical background according to reference format
- 2) Consolidate the lists for each type of plant
- 3) Review the function of the components
- 4) Decide the safety function of each components
- 5) Review the test items, frequency and so on
- 6) Comments on the difference between units for each type of plant

3. DEVELOPMENT OF TECHNOLOGY BACKGROUND FOR IST

The references for selecting the components subjected to technical background are current IST plan, FSAR Ch. 3, FSAR Ch. 6, FSAR Ch. 16, Emergency Operation Procedure (EOP), Probabilistic Safety Analysis (PSA) reports, Engineer Safety Feature (ESF) components, Safety Class components, and components of regulatory authority requirement.

Technical background is made in MS-Excel and Hangul word. Samples are shown in Figs. 1 and 2.

As a result the number of components subjected to technical background is

- 1) KSNP : Pump 43, Valve 886
- 2) PWR900 : Pump 35, Valve 708
- 3) CANDU : Pump 34, Valve 475

4. DEVELOPMENT OF STANDARD IST PLAN

IST plan of each plan was reviewed for standardization. At first standard form IST plan was composed regardless of plant type. And then specific features for specific plant type were reflected in the IST plan for each type. There was not significant difference in body of IST plan. The detailed items were attached in appendix.

