

## PSA

# Summary of Component Reliability Data for Probabilistic Safety Analysis of Korean Standard Nuclear Power Plant

,  
가  
150, [sychoi@kaeri.re.kr](mailto:sychoi@kaeri.re.kr)

3,4  
3,4  
1998 3,4 2000 3,4  
/  
/  
3,4 3,4 2002  
/ 가 / , PSA  
가 .  
.

### Abstract

The reliability data of Korean NPP that reflects the plant specific characteristics is necessary for PSA of Korean nuclear power plants. We have performed a study to develop the component reliability DB and S/W for component reliability analysis. Based on the system, we had have collected the component operation data and failure/repair data during plant operation data to 1998/2000 for YGN 3,4/UCN 3,4 respectively. Recently, we have upgraded the database by collecting additional data by 2002 for Korean standard nuclear power plants and performed component reliability analysis and Bayesian analysis again. In this paper, we supply the summary of component reliability data for probabilistic safety analysis of Korean standard nuclear power plant and describe the plant specific characteristics compared to the generic data.

1.

(KAERI)  
 3,4 3,4 PSA 가  
 (PSA, Probabilistic Safety Analysis), RIR&A (Risk Informed Regulation & Application), MR  
 (Maintenance Rule) PSR (Periodic Safety Review)

[1] [2] , 3,4  
 1998 3,4 2000  
 / / [3][4].  
 KAERI 3,4 2001 2002 / 가  
 / 3,4  
 / 가  
 (KOPEC) 1999 2002 3,4 PSA  
 / (KHNP)  
 [5].  
 1 2002 /  
 2 PSA  
 3 (generic data)

2.

2.1. /  
 1 3,4 3,4  
 /  
 1. 3,4 3,4 /

			/	
3,4	- 2002.12.31	KAERI		, ,
3,4	- 1998.12.31	KAERI		, ,
	1999.1.1 - 2002.12.31	KOPEC	PSA	
	1999.1.1 - 2002.12.31	KAERI	KOPEC 가	, ,

2.

			( )
YGN-3	1995-4-1	2002-12-31	7.75
YGN-4	1996-1-1	2002-12-31	7
UCN-3	1998-8-11	2002-12-31	4.39
UCN-4	2000-1-1	2002-12-31	3

- ✓ : KHNP 3,4 3,4  
 (TR : Trouble Report) DB . TR DB Excel ,  
 PUMAS/N-II, PUMAS/N-III DB .
- ✓ TR : TR , ,  
 / 가 . TR  
 '가 .
- ✓ : TR  
 / 가 .  
 가 가 .
- ✓
- ✓ 5,6 PSA TR
- ✓ / TR 가 .  
 TR /
- ✓ TR ( ) OOS  
 , ( )  
 가 ,  
 가 .

2.2.

KAERI

PSA

1998 . 가 , 3,4 , 2002 , 3,4  
 , KOPEC 3,4 1999 2002 3 24

PSA

3.

SI	Safety Injection/Shutdown Cooling	WT*	Turbine BLDG Closed Cooling Water
CS	Containment Spray	DG	Class 1E Diesel Generator
CV	Chemical & Volume Control System	IA	Instrument Air
SD	Steam Generator Blowdown	VD	D/G Room HVAC
CC	Component Cooling Water	VH	Intake Structure/Pump House HVAC
SX	Essential Service Water	VY	ECCS Equip. Room HVAC
MS	Main Steam	WO	Essential Chilled Water
FW	Feed Water	FP	Fire Protection
AF	Aux. Feed Water	MP	Main Power System
CW*	Circulating Water	AP	Auxiliary Power System
SW*	Travelling Screen & Screen Wash	DC	DC Distribution
WH*	Turbine BLDG Open Cooling Water	IP	I&C Power System

\* PSA

4.

	ACU		Air Dryer
	Chiller		Compressor
	Diesel Generator		Fan
	Filter (Debris Filter, Dryer Assembly)		Strainer
*	Traveling Screen		
	Check Valve		Manual Valve
	Motor Operated Valve		Pneumatic Operated Valve
	Solenoid Operated Valve		
	Pump (AFW Diesel Pump, AFW Motor Pump, AFW Turbine Pump, CCW Pump, Charging Pump, CS Pump, ECW Pump, ESW Pump, HPSI Pump, LPSI Pump,	*	Pump (Circulating Water Pump, MFW Turbine Pump, TBCCW Pump, TBOCW Pump)
	Battery		Battery Charger
	Bus		Circuit Breaker
	Inverter		Transformer
	Element (Flow, Temperature, Etc)		Switch (Differential Pressure, Flow, Level, Pressure, Temperature)
	Transmitter (Differential Pressure, Flow, Level, Pressure, Temperature)		

\* PSA

3  
 4 I&C 3,4 1998  
 4 traveling screen TBOCW/TBCCW PSA  
 PSA

2.3.

Fails to Run  
 Fails to Start, Fails to Operate  
 PSA 가  
 2002 [3]  
 2002 PSA 가  
 [3], PSA 5  
 3,4 PSA

5. 3,4

3451CV-V0305	RWT Disch. Line Cehck Valve CH-305	3	3	12		1	3 HPSI, LPSI, CS pp -1 (Hpsi), -2 (Lpsi), -21 (Cs)
3441M-PP02A	HPSI PUMP-1	3	1	4		0.333	- -01 miniflow line
3441SI-V0675	Contt' Sump Iso. MOV SI-675	3	1	4		0.333	- -34 14.1
3633M-PP01A	Essential Chilled Water Pump	2	1	6	4.9	0.908	가 ( - 49, 3 , / chiller / , CV , CCW Iso MV / ) ( -39, 1 /1 ) -39 - 49

3.


/

5,6 PSA

(prior) (Bayesian)

1

(posterior) 가



1.

3.1.

1, 2, 3가

20% 가

20%

가

(Pump External Leakage, Valve External, Internal Leakage

)

가

✓ : = + \* 0.2

✓ : = + +

3가

✓ 1 /h = / Plant

✓ 2 /h = /

✓ = /

3.2.

6.

Case		Case	
Case 1	3,4 2002 ( )	Case 1G	.
Case 2	3,4 2002 , 3,4 1998 ( )	Case 2G	.
Case 3	3,4 3,4 2002 (PSA )	Case 3D	PSA 가 가
		Case 3G	.
Case 4	1998 (I&C )	Case 4G	.
Case 5	Data		
Case 6	. Pump		

3,4 2002  
, 3,4 1998  
(Case 2), 1999 2002 PSA (Case 3),  
(Case 1)  
I&C 1998 Case 4  
, Case 1G, 2G, 3G 4G  
가  
, Case 5  
10 가  
. Case 6 가

3.3.

가 , 10 가  
가 가 . 가  
가 . 가 0 ,

Bayesian

가

Bayesian

$$f(\lambda | E) = \frac{f(\lambda)L(E | \lambda)}{\int_0^\infty f(\lambda)L(E | \lambda)d\lambda}$$

$E$  (observation)

$\lambda$  (parameter)

$f(\lambda/E)$

$E$

$L(E/\lambda)$

$\lambda$

$E$ 가

Likelihood

$f(\lambda)$

(generic data)

가

BURD

[6]

5,6 PSA

Likelihood

4.

3

PSA

4.1.

7

7


1 /h	/ Plant
2/h	/
	/
	5,6 PSA
	. /h , (/d)



7.

		/h <sup>1</sup>	/h <sup>2</sup>				
Battery Charger	No Output	4.58e-6			0.654	7.00e-6	/h ( 1)
Bus	Fails while Operating	9.52e-8			0.476	2.00e-7	/h ( 1)
Chiller	Fails to Run		3.11e-4		31.1	1.00e-5	/h ( 2)
Chiller	Fails to Start	3.27e-5		2.60e-2	4.333	6.00e-3	( )
Compressor	Fails to Run		6.42e-5		0.642	1.00e-4	/h ( 2)
Compressor	Fails to Start	2.04e-5		2.00e-2	1	2.00e-2	( )
element - Flow	Failure	3.38e-7			0.125	2.70e-6	/h ( 1)
Inverter	Failure	7.33e-6			0.366	2.00e-5	/h ( 1)
Power Operated Valve - Motor	Spurious Operation	4.04e-7			2.885	1.40e-7	/h ( 1)
Power Operated Valve - Motor	Fails to Operate	6.89e-7		1.35e-3	0.337	4.00e-3	( )
Pump - AFW Motor Pump	Fails to Run					1.50e-4	/h ( 2)
Pump - AFW Motor Pump	Fails to Start	1.34e-5		8.82e-3	2.94	3.00e-3	( )
Pump - Motor	Fails to Run		2.03e-5		0.812	2.50e-5	/h ( 2)
Pump - Motor	Fails to Start	5.03e-6		5.40e-3	2.347	2.30e-3	( )
Switch - Flow	Fails to Operate	2.91e-7			0.223	1.30e-6	/h ( 1)
Switch - Flow	Spurious Operation	7.27e-7			0.519	1.40e-6	/h ( 1)
Transmitter - Flow	Failure	4.76e-6			1.106	4.30e-6	/h ( 1)

2 PSA



2.

4 PSA , 48  
 가 ,  
 가 4  
 33 75% 0.25  
 5 'failure', ACU 'fails to run', 'fails to run'  
 , 4.0 6  
 'fails to run' 가 , 'fails to start',  
 'failure', 'spurious operation'

4.2. PSA

5,6 PSA

가  
 8 PSA 8 7  
 8

	( ) Error Factor (Lognormal )
	. /h , (/d)

6

		6 Case
1	3,4 3,4 2002 / (PSA )	Case 1
2	3,4 2002 3,4 1998 / (PSA )	Case 2
3	3,4 3,4 2002 / (PSA )	Case 3
3D	3,4 3,4 2002 / ( 가 PSA )	Case 3D
4	3,4 1998 (I&C )	Case 4
5	5,6 PSA	Case 5
6	3,4 3,4 2002	Case 6

8. PSA

	Chiller	Fails to Run	2.90e-4	1.17	/h	3
	Chiller	Fails to Start	1.90e-2	1.40	(/d)	3
	Diesel Generator	Fails to Run	2.40e-3	3.20	/h	5
	Diesel Generator	Fails to Start	4.49e-2	1.33	(/d)	3
	Compressor	Fails to Run	7.01e-5	1.48	/h	3
	Compressor	Fails to Start	1.87e-2	1.76	(/d)	3
	Pump - AFW Motor Pump	Fails to Run	1.50e-4	16	/h	5
	Pump - AFW Motor Pump	Fails to Start	7.07e-3	2.08	(/d)	3
	Pump - Motor Pump	Fails to Run	2.02e-5	1.23	/h	6
	Pump - Motor Pump	Fails to Start	5.17e-3	1.40	(/d)	3D
	Pneumatic Operated Valve	Spurious Operation (Fails to Remain Open/Close)	3.80e-7	1.41	/h	1
	Pneumatic Operated Valve	Fails to Operate	8.55e-3	1.53	(/d)	3D
	Battery Charger	No Output	5.64e-6	1.62	/h	2
	Element - Flow	Failure	1.90e-6	1.24	/h	4
	Element - Temperature	Failure	8.49e-7	1.27	/h	4
	Transmitter - Flow	Failure	4.52e-6	1.26	/h	4

4.

1 2002 /

2 PSA

3 (generic data)

(KAERI)

3,4 3,4 , PSA

3,4 2001 2002 /

가 / , 1999 2002 3,4 PSA

KHNP KOPEC /

/ /

가 가 48 4 가 ,

가 4

33 75% 0.25

5 , 4.0 6 .

PSA 5,6

PSA

( 8).

PSA

가 .

KEPRI, 2 2 , , ,  
 . 3,4 1999  
 KOPEC .

1. , “ ”, KAERI/TR-2132/2002, 2002
2. , “ DB ”, KAERI/TR-2130/2002, 2002
3. , “ ”, KAERI/TR-2129/2002, 2002
4. , “ DB ”, 2002 , 2002
5. , “ ( -2002 )”, KAERI/TR-2749/2004, 2004 (to be published)
6. , “Bayesian BURD ”, KAERI-ISA-MeMO-PSA-2001-024, , 2002