

Table III: Power Errors of DEFENS for MDR

Thermal Power (MW)	Fission Power (MW)	RMS Error (%)	Max. Error(%) /Pos.
2061.40	2156.01	1.64	2.60/E-8

Table IV: Max. Powers of Channel and Bundle for MDR

	RFSP	DEFENS
Max. Channel Power(KW)/Pos.	9238.14/M-12	9206.35/M-12
Max. Bundle Power(KW)/Pos	1457.35/M-12, Bundle 5	1453.06/M-12, Bundle 5

Table V: Rel. Errors of Max. Powers of Channel and Bundle for MDR

Rel. Err. of Max. Channel Power(%)	-0.34
Rel. Err. of Max. Bundle Power(%)	-0.29

3. Bi-Directional Refueling

In this section, bundle peaking factor results are added for a comparison. It can be calculated by dividing the maximum bundle power by the average bundle power.

Table VI: Multiplication Factor for BDR

RFSP	1.02748
CANDUCS-DEFENS	1.02750




Fig. 4. Fast and Thermal Flux Distribution on yz-plane for BDR

XXXX RFSP (Reference)										
X.XX FEM (Relative Error, %)										
2750	2648	2526								
4.15	3.56	2.90								
3698	3591	3389	3121	2713	2289					
-0.69	-0.76	0.31	2.17	2.24	-0.13					
4671	4557	4333	4003	3570	3062	2560				
-0.98	-0.80	-0.81	-1.12	-1.84	-1.92	-0.88				
5578	5460	5225	4878	4421	3875	3256	2646			
-1.25	-1.02	-0.85	-0.87	-1.10	-1.79	-1.93	-0.89			
6374	6253	6014	5661	5192	4622	3964	3246	2537		
-1.23	-0.94	-0.71	-0.60	-0.64	-0.85	-1.34	-1.41	2.46		
7033	6911	6673	6360	5885	5304	4622	3868	3092		
-1.20	-0.91	-0.68	-0.65	-0.62	-0.64	-0.66	-1.09	2.14		
7645	7518	7268	6901	6423	5875	5185	4407	3553	2737	
-1.20	-0.87	-0.67	-0.44	-0.29	-0.25	-0.17	-0.19	1.26	-6.85	
8182	8049	7786	7399	6904	6346	5647	4856	3976	3099	
-1.12	-0.94	-0.73	-0.55	-0.30	-0.18	0.06	0.14	0.50	4.57	
8643	8504	8227	7818	7270	6658	5988	5192	4294	3349	2444
-1.07	-0.84	-0.70	-0.49	-0.17	0.15	0.33	0.56	1.19	3.42	10.00
8965	8821	8534	8110	7542	6914	6239	5437	4529	3565	2601
-0.94	-0.83	-0.64	-0.50	-0.18	-0.04	0.24	0.50	1.26	2.06	8.89
9122	8976	8684	8253	7676	7042	6363	5558	4645	3673	2703
-0.60	-0.44	-0.37	-0.21	0.03	0.22	0.40	0.68	1.48	2.42	9.46

Fig. 5. Power and Error Distribution of RFSP and DEFENS for BDR

Table VII: Power Errors of DEFENS for BDR

Thermal Power (MW)	Fission Power (MW)	RMS Error (%)	Max. Error(%) /Pos.
2061.40	2156.01	1.51	2.08/E-7

Table VIII: Max. Powers of Channel and Bundle for MDR

	RFSP	DEFENS
Max. Channel Power(KW)/Pos.	9124.56/M-12	9109.76/M-12
Max. Bundle Power(KW)/Pos	1465.88/M-12, Bundle 6	1473.83/M-12, Bundle 7

Table IX: Rel. Errors of Max. Powers of Channel and Bundle for MDR

Rel. Err. of Max. Channel Power(%)	-0.16
Rel. Err. of Max. Bundle Power(%)	0.54

Table X: Bundle Peaking Factors for Refueling Methods

	MDR	BDR
Avg. Bundle Power(KW)	452.06	452.06
Max. Bundel Power(KW)	1453.07	1473.83
Loc. of Max. Bundle Power	M-12 Bundle 5	M-12 Bundle 7
Bundel Peaking Factor	3.21	3.26

4. Conclusions

In this research, the results of RFSP and DEFENS codes are compared with each other for cases of MDR and BDR. For both cases, the multiplication factor error is extremely small, but the power errors are larger than those of mathematical initial core calculation. For the predictions of locations of max. rel. power err., max. channel power and max. bundle power, the DEFENS code prediction is matched well with the result of RFSP except for the prediction of location of max. bundle power for the BDR case. However, this is not a problem because the power difference between bundle 6 and 7 is negligible for the BDR case. In Fig. 2, Fig. 4, and Table X, it can be verified that the center of power distribution is moved to the centre of the core. Using the BDR, the max. bundle power increased while the avg. bundle power is not changed. In Table II and VI, it is also verified that the BDR can reduce the excess reactivity of the core. It seems that solving the realistic initial core problem is a way to investigate the soundness of the CANDUCS code.

5. Acknowledgement

This work was supported by the National Research Foundation of Korea(NRF) grant funded by the Korea government(Ministry of Science, ICT, and Future Planning) (No. NRF- 2012M2A8A4012022)

REFERENCES

- [1] Design Manual, KHNP, CANDU 6 Generating Station, Physics Design Manual, Wolsong NPP 1, 59RF-03310-DM-000 Revision 0, 2009.
- [2] P. Schwanke, RFSP-IST Version REL_3-04: Users' Manual, SQAD-06-5054, 153-117360-UM-002, CANDU Owners Group Inc., Dec., 2006.
- [3] S.R. Douglas, WIMS-AECL Release 2-5d User's Manual, COG-94-52(Rev. 4), FFC-RRP-299, AECL, Jul., 2000.
- [4] T. Liang, WIMS Utilities Version 2.0: User's Manual, SQAD-07-5087/WP51508, 153-119220-UM-001, CANDU Owners Group Inc., Jun., 2007.