


A Study on Equipment Protection during Hydrogen Burn

150



Abstract

The experiment on study for equipment protection during hydrogen burn was carried out. When the quenching mesh with 0.3 mm quenching distance surrounds a model equipment (10x10x10cm), the role of quenching mesh was experimentally examined. The thermo-couple is installed at 10mm far from the model equipment surface. The dimension of combustion chamber is 300x300x900 mm. The ignition starts at the one-end and propagates to the other-end. The gas temperature is measured using thermo-couple during hydrogen burn with mesh or without mesh around the model equipment. The direction of the chamber is horizontal or vertical. The maximum gas temperature is about 250 °C to 350 °C at the surface of the model equipment for without mesh. Meanwhile, the maximum gas temperature is less than 100 °C with mesh. In conclusion, quenching mesh could play a role of protecting a equipment during hydrogen burn because the verification temperature of the equipment by manufacture is from 190 °C to 250 °C.

1.

가 , , TMI -
2[1] 가

[2], APR1400[3] EPR[4]

가 Lumped
가 가 가
가 [5].

가 가 가 가
가 가 가 [6],
가 [7] 가 가

가 가 가 가
가 가 가 [8]
0.3mm 1 (29.7 %) 가

가 DDT 가
[9, 10].
가

2.

2.1

1 , 2
3 (300x300x300 mm) 가 900 mm가
가 180x180 mm

(2) 가
400 V 가 16.5 kV 가 가 140 V
2 mm Ch 1-3

Ch 2-1 Ch 3-3

SIEMENS, 7MF4032

PCB Piezotronics Inc. W112A02

DAS

PC K-type sheath
 3 0.3mm
 (Ch 1-2 2-
 2) 4
 100x100x100 mm
 2 Ch2-2 T/C
 T/C T/C 4
 10mm
 4 가 , 4 , Mirror-I
 , Mirror-II (1), 5
 , 6

1
 Xe lamp Tungsten lamp가 F8 Convex
 mirror가 Convex Mirror Mirror-I Mirror-I
 (8 inch) 8x8=64 inch 1.63 m Mirror-I beam
 Mirror-II Mirror-II 2
 Mirror-II Mirror-II
 Mirror-II 2m 20

2.2

, DAS,
 Mirror , 가
 가
 (Vision research Inc., Phantom V4.0) 512x512 pixels 1,000 pictures per
 second(pps) . DAS , 가
 가 가
 가 가 20
 (ComVac, HJD2120V) -0.9bar 2-3
 가 , -0.9bar
 0.1 50 °C
 가 가 Hair Dryer 가
 Vent (2 Ch 3-2) 가
 0 bar가

2 Ch 3-3 (: 4)

가

5

DAS

3.

가

(8% 11%)

가 가

가

가
11%

가 7
550 °C

3.3 bar 가
가
8

가 가
가

가 가 가

가

1.2 m/s

(Shadow)

가

10% 가
3.5 bar

가 (9).

가
10

(4) , ,
8

가

가 가 , 10
가

Mirror-I

가

Mirror-I Mirror-II

가

200 °C 350 °C 2
가 200 °C


1

190 °C 250 °C


, , 11
 10% 가 가 가 , 9
 가가 (4)
 , , 100 °C
 . 12
 . ,
 .
 4.
 가
 가
 100 °C
 가 11% 가 가
 1.2m/s , 가
 가

1. NASC, 1980, "Three Mile Island Unit 2 Accident," Nuclear Safety Analysis Center Report
2. YGN 3&4, FSAR
3. KNGR, PSAR
4. Nuclear Safety NEA/CSNI/R(99)16, "State of Art Report on Containment Thermal-hydraulics and Hydrogen Distribution", June 1999
5. KOPEC, " 가 "
6. S. W. Hong, H. D. Kim, H. J. Kim, S. H. Chung: Installation method of Quenching grid for Hydrogen Control in Pressurized Water Reactors, Patent Registration No: 0335830, Korea, 2002
7. H. J. Kim, S. W. Hong, H. D. Kim, S. Y. Yang, S. H. Chung: Quenching Distance Measurement for the Control of Hydrogen Explosion, CD-Rom Proc., 18th ICDERS, USA, 2001


8. Phillips, H., 1963, "On the Transmission of Explosion through a Gap Smaller than the Quenching Distance," *Combustion and Flame*, 7, pp. 129-135
9. Seong-Wan Hong, Yong-Seung Shin, Jin-Ho Song, "PERFORMANCE TEST OF THE QUENCHING MESHES FOR HYDROGEN CONTROL", *Journal Nuclear Science and Technology, AESJ*, in progress
10. S.W. Hong, Y.S. Shin, J. H. Song, H. D. Kim, H.J. Kim, "Visualization study of flame propagation during hydrogen combustion with quenching mesh", *PSFVIP-4*, June 3-5, 2003




1.




2.




3.




4.




5.




6.





7. 11%



가 ()




8. (10%, Time interval : 30ms)





9.

(Mesh가)




10.

(10%, Time interval : 50ms)




11.


(Mesh가)



(1)




(2)




(3)



(4)



(5)



(6)

12.

(10%, Time interval : 40ms)

1.

Components	제작사 검증온도	
	F	C
SDSMOV	375	191
SDS MOV 제어용 전선	464	240
압력전송기	482	250
계측용 전선	420	216
CET에 연결된 계측용 전선	482	250
junction panel	375	191
RTD 계측용 전선	482	250
HJTC probe, head lift rig junction panel		
refueling disconnect panel 및		
이들을 통하여 EPA까지 연결하는 전선	375	191
증기발생기 수위전송기(LT)	420	216
계측용 전선	482	250
격납건물 격리밸브	375	191
제어용 전선	482	250
격납건물 대기 방사선감지소자(RE)	375	191
방사선감지소자관련 계측용 전선	482	250
격납건물집수조 수위감지소자(LE)	375	191
계측용 전선	482	250