

2001

가

**Seismic Fraility Evaluation of Diesel Generator Mounted on  
Vibration Isolator**

360-9

103-16

0.2g                      RG 1.60

가

가                      HCLPF      0.39g

Nuclear power plants in Korea are seismically-designed based on the RG 1.60 standard spectrum anchored to 0.2g. All the safety-related equipment including diesel generator should be seismically qualified by testing or analysis. However, diesel generator mounted on the spring isolator is well known to be vulnerable when subjected to the earthquake exceeding design level. The seismic performance level of the diesel generator was evaluated using the seismic fragility approach. The HCLPF (High Confidence and Low Probability of Failure) capacity of the diesel generator is 0.39g.

1998

- 가 가

$$A_{HCLPF} = A_m \times e^{-1.65(b_R + b_U)}$$

$A_{HCLPF}$  : HCLPF

$A_m$  : 가

$b_R$  :

$b_U$  :

가

가 가

1.100

- 가

SRP 3.10

가

IEEE-344

가

가  
가

가

가

가

, IEEE-344

가

가

GL 88-20

가

가

가가

가

가 5%

가


가

95%

가

2	2.58 Hz	0.245	91%
3	3.23 Hz	0.215	100%
4	3.49 Hz	0.425	-
5	3.72 Hz	0.310	9%
6	5.43 Hz	0.510	6%

W = 172000kg



1 :

: DIN 17221

: GERB GP 8.721

d = 21mm

D = 97mm

$L_o = 185\text{mm}$

$k_h = 2490 \text{ N/mm}$

$k_v = 3560 \text{ N/mm}$

: GERB VH6-SP1

$C = 250000 \text{ N/m/s}$

1	2.46 Hz	0.235	94%
---	---------	-------	-----

- EPRI TR-103959

가

- EPRI TR-103959

가

가

가


가

3Hz

7 Hz

가

2



2 :

가

$$F_H = \frac{S_{a(5\% \& 2.5 Hz) FRS}}{S_{a(5\% \& 2.5 Hz) GRS}} = \frac{0.74g}{0.66g} = 1.12$$

NUREG/CR-0098

$S_v$	0.11 m/sec	0.07 m/sec
$S_a$	0.176 g	0.150 g
$S_d$	7.01 mm	3.66 mm

$$k_h = 49800 N / mm$$

$$k_{xx} = 2.395 \cdot 10^6 N \cdot m / rad$$

$$q_{yy} = 3.12 \times 10^{-3} \cdot rad$$

$$\Delta_x = 5.969 mm$$

$$\Delta_z = 1.626 mm$$

$$k_h = 49800 N / mm$$

$$k_{yy} = 8.255 \times 10^8 N \cdot m / rad$$

$$q_{xx} = 1.071 \times 10^{-3} \cdot rad$$

$$\Delta_x = 5.969 mm$$

$$\Delta_z = 2.184mm$$

3.658mm

100-40-40

DIN 17221

21 mm

가

6.426 mm

$$: t_a = 830N/mm^2$$

$$: s_u = 1480 \cdot N/mm^2$$

EPRI TR-103959

$$Q(N) = 2002 \cdot F_S$$

62%

$$P_v(N) = 1913 \cdot F_S + 10545$$

$F_S$

$$F_v = 1011 \cdot N/mm^2$$

$R_T$

$$R_T = \frac{g_o}{R_c} + b_o - g_o$$

$$t_p = \frac{8 \cdot P_v \cdot D}{p \cdot d^3}$$

$$R_c = \frac{C_p}{C_q} = 0.699$$

$$, C_p = 311.25N/mm$$

$$t_m = t_p \cdot \left(1 + \frac{Q}{P_v} \times R_T\right)$$

$$, C_q = 445N/mm$$

$$F_S = 4.4$$

$$b_o = \frac{L_o}{D} = 1.907$$

$$g_o = \frac{f_p}{D} = 0.063$$

$$f_p = \frac{P_v}{C_p} = 0.242in$$

$R_T$

$$R_T = 0.0019 \cdot F_S + 2.005$$

가 . EPRI TR-

103959

가 .

0.12

가 가 .

$$b_R = 0.0$$

$$F_d = 1.0$$

$$b_R = 0.0$$

$$b_{U\_strength} = 0.12$$

$$b_U = \ln\left(\frac{AF_{15\%}}{AF_{50\%}}\right) = \ln\left(\frac{1.20}{1.05}\right) = 0.13$$

$$b_{U\_DL} = 0.03$$

$$b_{U\_equation} = 0.05$$

$$b_U = \sqrt{(b_{U\_strength}^2 + b_{U\_DL}^2 + b_{U\_eqn}^2)} = 0.13$$

0.10,

0.05

가 .

$$F_M = 1.0$$

$$b_R = 0.0$$

$$b_{MF} = \ln\left(\frac{S_{a-2.76Hz}}{S_{a-2.5Hz}}\right) = \ln\left(\frac{0.200g}{0.176g}\right) = 0.13$$

$$b_{MS} = 0.05$$

$$b_U = \sqrt{(b_{MF}^2 + b_{MS}^2)} = 0.14$$

가

1.0

가

가 .

0.05

$$F_{MC} = 1.0$$

$$b_R = 0.0$$

$$b_U = 0.05$$

mean-1σ

15%

15%

1.2

3σ

$$F_{ECC} = 1.0$$

$$b_R = 0.0$$

$$b_{U-H} = \frac{1}{3} \ln\left(\frac{\Delta_{ABS}}{\Delta_{SRSS}}\right) = \frac{1}{3} \ln\left(\frac{0.332''}{0.253''}\right) = 0.09$$

$$b_{U-V} = \frac{1}{3} \ln\left(\frac{\Delta_{ABS}}{\Delta_{SRSS}}\right) = \frac{1}{3} \ln\left(\frac{0.294''}{0.169''}\right) = 0.18$$

$$b_U = 0.12$$

가

가

7Hz

0.2

0.05

$$F_{SA} = 1.0$$

$$b_R = 0.2$$

$$b_U = 0.05$$

EPRI TR-103959

0.10

$$F_{HED} = 1.0$$

$$b_R = 0.10$$

$$b_U = 0.0$$

0.05

$$F_{ECC} = 1.0$$

$$b_R = 0.0$$

$$b_U = 0.05$$

$$F_O = 4.4$$

$$b_R = 0.26$$

$$b_U = 0.24$$

0.2g

가

가

$$A_m = F_m \times PGA = 0.88 \cdot g$$

HCLPF

$$A_{HCLPF} = A_m \times e^{-1.65 \cdot (b_R + b_U)} = 0.39 \cdot g$$

		$b_R$	$b_U$
$F_S$	4.4	0.0	0.13
$F_m$	1.0	0.0	0.0
$F_d$	1.0	0.0	0.13
$F_M$	1.0	0.0	0.14
$F_{MC}$	1.0	0.05	0.0
$F_{ECC}$	1.0	0.12	0.0
$F_{SA}$	1.0	0.2	0.05
$F_{HED}$	1.0	0.10	0.0
$F_O$	4.4	0.26	0.24

가 Engine - EDG Engine Qualification  
 Synthesis Report, by S.E.M.T.  
 Pielstick, M263-ER-A01-04 Rev.1.

가 . 3. Seismic Qualification of PC 2-5  
 Engine - Seismic Analysis of the  
 Engine, by S.E.M.T. Pielstick,  
 M263-EP-A01-07 Rev.1.

가 4. EDG Units Generator Dynamic  
 Qualification Report, by Gegelec,  
 M263-ER-A01-01, Rev. 1.

가 , 5. Resilient Mounting Calculation,  
 by S.E.M.T. Pielstick, M263-DG-  
 E01-03, Rev. 1.

가 , 6. Common Skid Calculation, by  
 S.E.M.T. Pielstick, M263-DG-E-01-  
 02.

가 , 7. Seismic Qualification of Piping,  
 MT6-94/221.

가 .  
 가가 , 가  
 가 가  
 가 .  
 가 ,  
 가 .

1. Seismic Qualification of PC 2-5 Engine, Qualification Description, by S.E.M.T. Pielstick, M263-EP-A01-02 Rev.1.
2. Seismic Qualification of PC 2-5