

# **The Safety Assessment of OPR-1000 for Station Blackout Applying Combined Deterministic and Probabilistic Procedure**

May 8, 2015



**한국원자력안전기술원**  
KOREA INSTITUTE OF NUCLEAR SAFETY

**Dong Gu Kang**  
**Seung-Hoon Ahn, Dae-Hyung Cho**

# Table of Contents





- 1. Introduction**
- 2. Combined Deterministic and Probabilistic Procedure (CDPP) for BDBA Assessment**
- 3. CDPP Application to OPR-1000 SBO Accident**
- 4. Reevaluation of Station Blackout Risk**
- 5. Conclusions**

# Introduction

## ❑ Station Blackout (SBO)

- AC power is essential for safe operation and accident recovery
  - Normally supplied by offsite power
  - Onsite power (EDG, AAC) if offsite power is lost
- Total loss of AC power (offsite/onsite) → **SBO**



## ❑ Risk of SBO

- Historically, SBO is an important contributor to overall plant risk
- Important contributors to SBO risk
  - Turbine-driven pumps (TDPs), DC battery depletion time, Characteristics of Offsite power restoration

## ❑ Safety assessment of OPR-1000 for SBO using CDPP


# CDPP for BDPA Assessment

## Terminology


$$P(CD) = P_{seq} \cdot P_{cond,exc}$$

$$\lambda_{CD} = \lambda_{IE} \cdot P(CD) = \lambda_{IE} \cdot P_{seq} \cdot P_{cond,exc}$$

- **Conditional exceedance probability (CEP,  $P_{cond,exc}$ )**
  - Probability that core will be damaged for a specific initiating and its sequence event
  - Acts as a go-between PSA and BEPU results




# CDPP for BDBA Assessment



# Application to OPR-1000 SBO


## System/Component for SBO mitigation




- DC battery : 4 hours
- Turbine driven pump (TDP) : when DC battery available
  - SG low level (23.8% WR)
  - Aux. feedwater injection with time delay of 46.45 sec after SG low level
- Recover offsite power : RACE (1 hr), RAEL (7 or 11 hr)
- Motor driven pump (MDP) : when offsite power recovered

# Application to OPR-1000 SBO

## System/Component for SBO mitigation



- Atmospheric dump valve (ADV)
  - Controlled by operator, 5 min after AFW injection, 50 °C/hr
- Main steam safety valve (MSSV)
  - Controlled by 2nd pressure (8.618/8.187 MPa)
- Pressurizer safety valve (PSV)
  - Controlled by PRZ pressure (17.24/14.07 MPa)






# Application to OPR-1000 SBO


## System/Component for SBO mitigation

- Safety injection tank (SIT) : PRZ P < 4.245 MPa
- RCP leakage : 1.32 L/s (21 gpm) from NUREG/CR-6995 (BNL)





# Application to OPR-1000 SBO



## ❑ Step 1 : Select BDBA (Initiating Event)

- Station Blackout
- Starting  $t=0$  when LOOP occurs

## ❑ Step 2 : Determine Targeted CDF & CCDP

- $CDF < 5.4E-7$ ,  $CCDP < 3.3E-2$   
[less than 10% of total CDF ( $5.44E-6$ )]

## ❑ Step 3 : Estimate IEF

- From PSA data,  $IEF(SBO)=1.60E-5$  based on domestic operation experience database

# Application to OPR-1000 SBO



## Step 4 & 5 : Identify Sequence of Events & Quantify SP

Station Blackout	AFW Using TDP	Recover Offsite Power (Early)	AFW Using MDP	Steam Removal Using MSADV	Steam Removal Using MSSV	Recover Offsite Power (Late)	NO	SP <sup>1)</sup>
SBO	AFT	RACE	AFM	SHR1	SHR2	RACL		
							1	9.31E-1
							2	3.78E-2
							3	2.484E-2
							4	2.76E-3
							5	3.173E-6
							6	1.386E-3
							7	4.458E-6
							8	4.246E-9
							9	1.185E-6
							10	2.27E-3

# Application to OPR-1000 SBO

## Step 6 : BEPU Application to Calculate CEP

- Preliminary estimation of CEPs for six sequences



- Sequence 2, 4, 10 result in core damage :  $P_{\text{cond,exc}} \sim 1.0$
- Sequence 1 has enough margin (CD occurs  $\sim 17$  hr) :  $P_{\text{cond,exc}} \sim 0.0$
- Sequence 6 has enough margin (RV water inventory) :  $P_{\text{cond,exc}} \sim 0.0$
- BEPU application for sequence 3 (CD  $\sim 7.8$  hr)

# Application to OPR-1000 SBO


- ❑ Step 7 : Select Simulation Code/Model (MARS-KS)
- ❑ Step 8 : Identify & Quantify Relevant Uncertainties

No	Parameter	Distribution	Mean	Range
1	Core power	Normal	1.0	0.98~1.02
2	Decay heat	Normal	1.0	0.934~1.066
3	PSV break CD	Normal	0.947	0.729~1.165
4	RCP seal leakage (L/s)	Uniform	1.32	0.06~2.58
5	Aux. feedwater flow rate (m <sup>3</sup> /min)	Uniform	1.985	1.89~2.08
6	SG low water level signal (%)	Uniform	21.5	19.9~23.1
7	PSV opening pressure (MPa)	Uniform	17.24	17.06~17.41
8	MSSV opening pressure (MPa)	Uniform	8.618	8.273~8.963
9	SIT actuation pressure (MPa)	Uniform	4.245	4.031~4.459
10	SIT water temperature (K)	Uniform	302.6	283.2~322
11	SIT water volume (m <sup>3</sup> )	Uniform	52.63	50.69~54.57
Core heat transfer & SG tube outer wall heat transfer				
12,13	Critical heat flux	Normal	0.985	0.17~1.8
14,15	Nucleate boiling heat transfer	Normal	0.995	0.53~1.46
16,17	Transition boiling criteria	Normal	1.0	0.54~1.46
18,19	Liquid convection heat transfer	Normal	0.998	0.606~1.39
20,21	Vapor convection heat transfer	Normal	0.998	0.606~1.39
22,23	Film boiling heat transfer	Normal	1.004	0.428~1.58

# Application to OPR-1000 SBO

## Step 9 : Calculate CEP

- 1,000 calculations (direct Monte-Carlo method) for sequence 3
  - Most of PCTs lie within the range of 635~643 K
  - All PCTs occurs immediately after the accident (4 sec)
  - There is not the case beyond PCT limit : CEP  $\sim$  0.0



Parameter	Result
No. of Case beyond 1477 K	0
$P_{\text{cond,exc}}$	$\sim$ 0.0
Average PCT	694.3 K
Max. PCT	1261.3 K
Min. PCT	635.7 K

# Application to OPR-1000 SBO

- Step 10~12 : Calculated CDF & CCDP < Acceptable Risk

Sequence No.	IEF	SP	CEP	CCDP	CDF
1	1.6E-5	9.31E-1	~ 0.0	~ 0.0	~ 0.0
2	1.6E-5	3.78E-2	~ 1.0	3.78E-2	6.048E-7
3	1.6E-5	2.484E-2	~ 0.0	~ 0.0	~ 0.0
4	1.6E-5	2.76E-3	~ 1.0	2.76E-3	4.416E-8
5	1.6E-5	3.173E-6	~ 1.0	3.173E-6	5.077E-11
6	1.6E-5	1.386E-3	~ 0.0	~ 0.0	~ 0.0
7	1.6E-5	4.458E-6	~ 0.0	~ 0.0	~ 0.0
8	1.6E-5	4.246E-9	~ 1.0	4.246E-9	6.794E-14
9	1.6E-5	1.185E-6	~ 1.0	1.185E-6	1.896E-11
10	1.6E-5	2.27E-3	~ 1.0	2.27E-3	3.632E-8
Sum				4.2834E-2	6.8535E-7

- Calculated CDF & CCDP for BDB LOCA meet the acceptable risk

$$P(\text{CD}|\text{SBO}) = 4.2834 \times 10^{-2} \not\leq 3.3 \times 10^{-2}$$

$$\lambda_{\text{CD}}(\text{SBO}) = 6.8535 \times 10^{-7} \not\leq 5.4 \times 10^{-7}$$

# Reevaluation of SBO Risk

## ❑ Reevaluation of SBO Risk

- Update of LOOP frequency reflecting latest operating experience
- Change of availability of component/system
- System design modification (DC battery capacity improvement)
- Change of TH analysis methodology in PSA

## ❑ Unavailability of offsite power restoration

- Most important contributor in SBO risk
- Time of offsite power restoration (RACL, RACE) by TH analysis
- Too much conservatism in RACL time of sequence 1,2
  - 11 hours (RACL time) vs 17.08 hours (CD time)
- SBO risk is reevaluated by proper estimation of RACL time



# Reevaluation of SBO Risk

## Reset of RACL time


- Unavailability of offsite power recovery
- SP of sequence 1, 2 : EPRI PRA assumption
- CEP of sequence 1 : BEPU calculation
- For RACL at 13 hours

$$\begin{aligned}P(\text{CD}|\text{SBO}) &= \sum_{i=1}^{10} P_{seq}(i) P_{cond,exc}(i) \\&= P_{seq}(1)P_{cond,exc}(1) + P_{seq}(2)P_{cond,exc}(2) + \sum_{i=3}^{10} P_{seq}(i) P_{cond,exc}(i) \\&= 0.9455P_{cond,exc}(1) + 0.02325 \times 1.0 + 5.034 \times 10^{-3} < 3.3 \times 10^{-2}\end{aligned}$$

$$P_{cond,exc}(1) < 4.99 \times 10^{-3}$$

$$P_{cond,exc}(1) < 9.02 \times 10^{-3} \text{ for RACL at 14 hours}$$



$$P_{cond,exc}(1) < 1.307 \times 10^{-2} \text{ for RACL at 15 hours}$$



# Reevaluation of SBO Risk

## Step 9 : Calculate CEP

- Calculations with 1,000 input sets for each RAEL time




- CEPs for RAEL time : 11HR ( $\sim 0.0$ ), 12HR ( $\sim 0.0$ ), 13HR (0.003), 14HR (0.154), 15HR (0.349)

# Reevaluation of SBO Risk

## Step 12 : CDF & CDP < Acceptable Risk

- Acceptable to reset RACL time to 13 hours



# Reevaluation of SBO Risk

## Step 14 : End of Evaluation

- Confirmed that current OPR-1000 has the acceptable risk for the SBO

Station Blackout	AFW Using TDP	Recover Offsite Power (Early)	AFW Using MDP	Steam Removal Using MSADV	Steam Removal Using MSSV	Recover Offsite Power (Late)	NO	SP <sup>1)</sup>
SBO	AFT	RACE	AFM	SHR1	SHR2	RACL		
							1	9.455E-1
							2	2.325E-2
							3	2.484E-2
							4	2.76E-3
							5	3.173E-6
							6	1.386E-3
							7	4.458E-6
							8	4.246E-9
							9	1.185E-6
							10	2.27E-3

# Conclusions

- ❑ Combined Deterministic and Probabilistic Procedure (CDPP) for BDBA Assessment
  - Three stages (PSA, BEPU, Combination) and thirteen steps
  - CEP estimated by BEPU method acts as a go-between PSA and BEPU
- ❑ Application to Station Blackout
  - Introduction to Station Blackout
  - Safety assessment of OPR-1000 for SBO
  - Reevaluation of SBO risk by proper estimation of RACL time
- ❑ CDPP is applicable to safety assessment of BDBAs in NPPs without significant erosion of the existing safety margin