



Fig. 4. Containment failure frequency with and w/o CFVS

Table IV: Fatalities with and w/o CFVS

| Category | Distance (km) | No CFVS | CFVS | Reduction ratio |
|------------------------------------|---------------|----------|----------|-----------------|
| Individual risk of early fatality | ~1.6 | 7.49E-08 | 7.40E-08 | 1.3% |
| | ~8.0 | 1.19E-08 | 1.18E-08 | 0.6% |
| | ~16.0 | 5.18E-09 | 5.15E-09 | 0.6% |
| | ~48.0 | 8.77E-10 | 8.72E-10 | 0.6% |
| | ~80.0 | 2.94E-10 | 2.92E-10 | 0.6% |
| Individual risk of cancer fatality | ~1.6 | 7.72E-08 | 7.62E-08 | 1.3% |
| | ~8.0 | 3.20E-08 | 3.14E-08 | 2.0% |
| | ~16.0 | 2.05E-08 | 2.01E-08 | 2.3% |
| | ~48.0 | 5.09E-09 | 4.86E-09 | 4.5% |
| | ~80.0 | 1.94E-09 | 1.85E-09 | 4.8% |

3. Conclusions

The CFVS is under installment in CANDU reactor for preventing the containment failure during severe accidents. But it has been evaluated that the effectiveness is negligible because of adverse effects of radioactive nuclides releases. Now the CFVS has not been installed yet in the LWR. The results can vary greatly depending on the detailed assessment. It is shown that this methodology might contribute to assessing the accident management strategy such as the implementation of the CFVS quantitatively. It can be used for improving EOPs and SAMGs.

Acknowledgements

This research was supported by a grant from the Nuclear Safety Research Program of the Korea Radiation Safety Foundation, with funding by the Korean government's Nuclear Safety and Security Commission (Grant Code: 1305008-0113-SB110), Institute for Basic Science and Innovative Technology Center for Radiation Safety.

REFERENCES

- [1] KINS, "Review on the requirements of containment filtered venting system performance", KINS/RR-1108, 2014.
- [2] Nuclear Energy Agency, "Status report on filtered containment venting, nuclear safety" NEA/CSNI/R(2014)7, 2014.
- [3] KHNP, "Probabilistic Safety Assessment for Ulchin Units 5&6: Internal Event Analysis, 2006
- [4] KHNP, "Analysis Report for Effect of Safety Enhancement According to the improvement of Korean NPP Safety Inspection (LWR: Unchin 5&6)", 2012.
- [5] KHNP, "Shin Kori 3&4 Probabilistic Safety Assessment (PSA) report", (2011)
- [6] D. Chanin and M. Young, "Code Manual for MACCS2: Volume 1, User's Guide", SAND97-0594, Sandia National Laboratories, 1997.
- [7] U.S. Nuclear Regulatory Commission, "Accident Source Terms for Light-Water Nuclear Power Plants", NUREG-1465, 1995.