

The maximum pressure drop recorded for the test was 19.73 kPa under the re-manufactured condition.

Table I: Test parameters

Parameter	Value
Temperature	22°C ± 1°C (between 21 and 23°C)
Flow Rates	77.6 lpm ± 3.8 lpm
Coolant Volume	1,810 liters
Fiber	15 g
Particulate Debris	15 g
AlOOH Chemical Product	768 g (70 liters of 11 g/L AlOOH surrogate)




Fig. 2. Pressure drops at P/F = 1

2.3 Calculation of the Bypass Fiber Amount

To establish the quantity of fibrous debris that could potentially penetrate the strainer, prototype test was performed [6]. The test was performed with only fibrous debris as adding particulates may reduce the amount of bypass debris due to clogging at the strainer. Additionally, the most conservative approach with bypass test is to assume all sump strainers are active running at the maximum flow rates since it stands to reason that more mass flow rate and more perforated plates causes more bypass. Table 2 lists the amount of fiber fines added and the amount of bypass fiber after each fiber addition [6].

Table II: Summary of fiber bypass

Fiber addition	Fiber added (g)	Bypass fiber amount (g)
First	37.2	1.213
Second	37.2	1.194
Third	74.4	2.057
Fourth	74.4	1.153
Fifth	74.4	0.851

To determine the plant strainer bypass debris, the cumulative quantity of bypass debris from the prototype test was scaled by a ratio of the plant strainer to the prototype strainer ($955/1.22 = 782.8$). The cumulative bypass quantities for debris loads are presented in Table 3. The total bypass debris is the sum of the bypass debris for all active strainers as presented in Table 4.

The amount of fibrous debris into the core are determined by the four safety injection pumps (SIPs) :

$$3.994\text{kg} \times 4 = 15.98\text{kg}$$

The SIP bypass amount during SIP+CSP operation : $15.58\text{kg} \times 1,235\text{gpm}/6,660\text{gpm} = 2.89\text{kg}$
However, a bigger value is used for conservative calculation.

Therefore, the amount of bypass fiber per FA in the APR1400 : $15.98\text{kg}/241\text{FA} = 0.0663\text{kg}/\text{FA} = 66.3\text{ g}/\text{FA}$

Table III: Cumulative prototype bypass debris

Fiber added(g)	Bypassed fiber weight(g)	Bypass rate(%)
37.2	1.213	3.26
74.4	2.406	3.23
148.8	4.463	3.00
132.2	5.616	2.52
297.6	6.467	2.17

Table IV: APR1400 bypass debris quantities

Pump	Flow rate (gpm)	Plant strainer debris load ¹ (kg)	Prototype strainer debris load ² (g)	Prototype bypass debris(g)	Bypassed fiber mass (kg)
SIP+ CSP	6,660	718.0	917.2	19.9 ³	15.58
SIP+ CSP	6,660	718.0	917.2	19.9 ³	15.58
SIP	1,235	133.1	170.1	5.1 ⁴	3.994
SIP	1,235	133.1	170.1	5.1 ⁴	3.994
Total	15,790	1,702.2			39.15

- 1) Proportion based on the flow rate: $1,702.2\text{kg} \times 6,660\text{gpm}/15,790\text{gpm} = 718.0\text{kg}$
- 2) Scaling by the surface area: $718\text{kg} \times 1.22\text{m}^2/955\text{m}^2 = 0.9172\text{kg}$
- 3) As the bypass rate decreases depending on increase of the fiber addition, applying the test result of 297.6 g in the Table 3: $917.2\text{g} \times 2.17\% = 19.9\text{g}$
- 4) Apply the test result of 148.8g in the Table 3: $170.1\text{g} \times 3\% = 5.1\text{g}$

3. Conclusions

In-vessel downstream effect tests with a mock-up PLUS7 fuel assembly were performed to confirm that the head losses caused by debris meet the available driving head following a LOCA. All the test results showed lower pressure drops than the available head limits. Therefore, a sufficient driving force is available to maintain an adequate flow rate, and the LTCC capability is adequately maintained in the APR1400.

A sensitivity test was conducted to assess the effect of a change in the gap size between the mock-up fuel assembly and the test column. The maximum pressure drop recorded for the test was 19.73 kPa under the re-manufactured condition. This value is larger by 1.6% than the previous test result (19.4 kPa) under the same conditions. As such, changing the gap of the flow path between the mock-up fuel assembly and the test column from the previous manufactured conditions to the re-manufactured conditions is expected to result in a slight increase in the differential pressure. However, this is a negligible amount compared to the test uncertainty value of 25%. Therefore, the results of test that have already been conducted are valid because there is a

plenty of margin under the limiting condition of hot-leg break.

Although the amount of calculated bypass fiber increased to 67.3 g/FA, conservatism was ensured by using 100g of fiber for the in-vessel downstream effect tests of the APR1400.

REFERENCES

- [1] APR1400-K-A-NR-14001-P Rev.1, "In-vessel Downstream Effect Tests for the APR1400," July 2015.
- [2] APR1400-K-A-NR-14002-P Rev.2, "In-vessel Downstream Effect Evaluation of the APR1400," July 2015.
- [3] J.K. Suh, et al., "In-vessel Downstream Effect Tests for the APR1400," Proceedings of ICAPP 2013, Jeju, Korea, April 14-18, 2013.
- [4] USNRC, "Final Safety Evaluation by the Office of Nuclear Reactor Regulation: Topical Report WCAP-16793-NP, Revision 2," April 2013.
- [5] J.K. Suh, et al., "Evaluation for the Impact of Debris Settling on the In-vessel Downstream Effect Tests of the APR1400 Design," Trans. of the KNS Spring Meeting, Jeju, Korea, May 7-8, 2015.
- [6] SKN-34325-021-001, "Candu's Response to KEPCO-ENC's Request on By-Pass Calculation Methodology," May 2014.