The background features a stylized illustration of a nuclear power plant with three cooling towers. A thick, vibrant green ribbon loops around the towers, and light blue, fluffy clouds are scattered in the sky above. The overall aesthetic is clean and modern, with a focus on environmental and safety themes.

# Preliminary Radioactive Contamination Assessment for Decommissioning on Kori unit 1 Bioshield

Korea Nuclear Society Autumn Meeting

Donghyun Lee, Hee Reyoung Kim

calvinj1@unist.ac.kr

# Outline

## ▪ Introduction

- Nuclear power plant bioshield concrete structure
- Research object
- Research implementation strategy

## ▪ Case study on similar foreign nuclear power plants

- Comparison on nuclear power plants decommissioning and decontamination environment
- Literature review on radioactive nuclide kind/ concentration assessment


## ▪ Assessment on bioshield activation

- Simplification of 3D geometry
- Reactor vessel division cell material properties
- Targeting major radioactive nuclide of interest
- MCNP6 based activation assessment


## ▪ Bioshield activation distribution analysis

## Nuclear power plant bioshield concrete structure

- Kori1. N.P.P. reactor vessel 3D geometry-simplification




[Fig1. Kori unit 1 reactor vessel 3D geometry]



[Fig2. PWR reactor vessel blueprint]


# Introduction

## Research object



# Introduction

## Research implementation strategy



# Case study on similar foreign nuclear power plants

## Benchmarking based on previous research

### ■ Former NPPs

[Table1. Foreign PWR nuclear power plants]

Plant name	Reactor type	Power (Mw(e))	Operation period (EFPY) (y)	Bioshield range (m)
Kori 1	PWR	576	40 (27.4)	3.16-5.30
Trojan	PWR	1095	16 (9)	3.08-5.03
Kewaunee	PWR	556	39 (21.9)	2.08-
Connecticut Yankee	PWR	560	28	
Rancho Seco	PWR	913	14 (6)	3.94-4.61
Shippingport	PWR	72	26 (12)	
Yankee-Rowe	PWR	167	31	
San onofre	PWR	436	24	
Indian Point 1	PWR	257	10	
Three Mile Island	PWR	792	2	

Lack of design parameters

※EFPY (Effective Full Power Years)


## Literature review on similar nuclear power plant

### ■ Trojan nuclear power plant

[Table2. Trojan nuclear power plant activation history]

	30 EFY (Effective Full Power Year)		
	0 years	10 years	100 years
Cooling time	0 years	10 years	100 years
Core shroud	1.13E+17	9.32E+15	1.66E+15
Core barrel	2.17E+16	1.79E+15	3.19E+14
Thermal shield	4.82E+15	3.98E+16	7.09E+13
Vessel cladding	4.20E+13	3.47E+12	6.17E+11
Vessel wall	4.33E+14	3.15E+13	9.92E+11
Upper grid plate	8.03E+14	6.62E+13	1.18E+13
Lower grid plate	1.82E+16	1.50E+15	2.68E+14
Bioshield	4.45E+13	2.89E+13	6.12E+11
Containment	1.80E+14	2.88E+13	6.12E+11
Totals	1.59E+17	1.31E+16	2.33E+15

Sample location(cm)	Radioactivity level in Bq/g			
	<sup>60</sup> Co	<sup>152</sup> Eu	<sup>154</sup> Eu	<sup>134</sup> Cs
315.6	7.03E+03	9.25E+03	9.99E+02	3.52E+02
350	8.14E+01	1.04E+02	1.04E+01	1.85E+00
380	1.15E+00	1.70E+01	2.04E+00	2.78E-01
407	2.11E-01	2.96E-01	3.37E-02	7.40E-03
446	7.03E-03	8.51E-03	None	None




[Fig 3. Trojan nuclear power plant activation degree]

# MCNP6 modeling scheme

## 3D geometry modeling

### ■ Kori1. N.P.P. reactor vessel 3D geometry



[Table2. Kori1. Cell geometry ]

Cell	Distance from the core (cm)
Core	138
Barrel	142
Bypass	146
Thermal shield	155
Downcomer	167
Pressure vessel	184
Air	316
Concrete	530


[Fig4. Kori 1 3D geometry (top view, cm)]



# MCNP6 modeling scheme

## 3D geometry modeling

### ■ Kori1. N.P.P. reactor vessel 3D geometry



[Fig5. Kori 1 3D geometry (side view, cm)]

[Table3. Kori1. Cell material ]

Structure	Medium
Core	UO <sub>2</sub> , Pu, H <sub>2</sub> O, Zr
Barrel	304 stainless steel
Bypass	H <sub>2</sub> O
Thermal shield	304 stainless steel
Downcomer	H <sub>2</sub> O
Pressure vessel	Carbon steel
Air	Air
Concrete	Concrete

# MCNP6 modeling scheme

## Reactor vessel input design

### ■ Kori1. NPP reactor vessel nuclei concentration data base

[Table4. Kori NPP unit 1 reactor vessel structural nuclei concentration]

Nuclide	Mass number	Core		Stainless steel		Pressure vessel		Bypass Downcorner(water)		Concrete		air	
		Number	Weight	Number	Weight	Number	Weight	Number	Weight	Number	Weight	Number	Weight
<sup>235</sup> U	235	1.15E-04	4.50E-26										
<sup>238</sup> U	238	6.64E-03	2.63E-24										
<sup>239</sup> Pu	239	3.70E-05	1.47E-26										
<sup>240</sup> Pu	240	8.86E-06	3.53E-27										
<sup>241</sup> Pu	241	3.57E-06	1.43E-27										
<sup>1</sup> H	1	2.76E-02	4.59E-26					4.83E-02	8.02E-26	7.41E-03	1.23E-26		
<sup>16</sup> O	16	2.68E-02	7.13E-25					2.41E-02	6.42E-25	4.21E-02	1.12E-24	1.05E-03	2.79E-26
<sup>10</sup> B	10	2.30E-06	4.E-29					4.31E-06	7.15E-29				
<sup>11</sup> B	11							1.77E-05	3.23E-28				
<sup>27</sup> Al	27	1.13E-06	5.05E-29							2.28E-03	1.02E-25		
<sup>12</sup> C	12	3.57E-06	7.11E-29	3.17E-04	6.32E-27	8.67E-04	1.73E-26					7.49E-07	1.49E-29
<sup>28</sup> Si	28			1.69E-03	7.88E-26	4.38E-04	2.04E-26			1.52E-02	7.09E-25		
<sup>50</sup> Cr	50	5.51E-07	4.58E-29	7.56E-04	6.28E-26	1.27E-05	1.05E-27						
<sup>52</sup> Cr	52	1.06E-05	9.17E-28	1.46E-02	1.26E-24	2.44E-04	2.11E-26						
<sup>53</sup> Cr	53	1.21E-06	1.06E-28	1.65E-03	1.45E-25	2.77E-05	2.44E-27						
<sup>54</sup> Cr	54	3.00E-07	2.69E-29	4.11E-04	3.69E-26	6.89E-06	6.18E-28						
<sup>55</sup> Mn	55	2.16E-06	1.97E-28	1.73E-03	1.80E-25	5.43E-06	4.96E-28						
<sup>54</sup> Fe	54	3.60E-06	3.23E-28	3.44E-03	3.09E-25	4.86E-03	4.36E-25						
<sup>56</sup> Fe	56	5.60E-05	5.21E-27	5.35E-02	4.98E-24	7.55E-02	7.02E-24			2.98E-04	2.77E-26		
<sup>57</sup> Fe	57	1.28E-06	1.21E-28	1.23E-03	1.16E-25	1.73E-03	1.64E-25						
<sup>58</sup> Fe	58	1.71E-07	1.65E-29	1.63E-04	1.57E-26	2.31E-04	2.22E-26						
<sup>58</sup> Ni	58	9.91E-05	9.55E-27	5.10E-03	4.92E-25	4.01E-04	3.86E-26						
<sup>60</sup> Ni	60	3.08E-05	3.07E-27	1.97E-03	1.96E-25	1.54E-04	1.54E-26						
<sup>61</sup> Ni	61	1.66E-06	1.68E-28	8.55E-05	8.66E-27	6.71E-06	6.80E-28						
<sup>62</sup> Ni	62	5.52E-06	5.68E-28	2.72E-04	2.81E-26	2.14E-05	2.20E-27						
<sup>64</sup> Ni	64	1.35E-06	1.43E-28	6.94E-05	7.38E-27	5.45E-06	5.79E-28						
<sup>96</sup> Mo	96					2.81E-04	4.48E-26						
<sup>91</sup> Zr	91	4.52E-03	6.83E-25										
<sup>23</sup> Na	23									1.00E-03	3.82E-26		
<sup>24</sup> Mg	24									1.42E-04	5.65E-27		
<sup>32</sup> S	32									5.38E-05	2.86E-27		
<sup>39</sup> K	39									6.61E-04	4.28E-26		
<sup>40</sup> Ca	40									2.78E-03	1.85E-25		
Total		6.60E-02	4.15E-24	8.70E-02	7.74E-24	8.48E-02	7.81E-24	7.24E-02	7.22E-25	7.20E-02	2.24E-24	1.05E-03	2.79E-26
Density			4.15		7.74		7.81		0.722		2.24		0.0279


- MCNP6 input
  - Weight fraction
  - Atom density fraction
  - Structural density
  - Structural volume

# Activation degree analysis

## Targeting major radioactive nuclide

### Target radioactive nuclei selection

- Selection criteria ( $^{60}\text{Co}$ )
  - Major long-living  $\gamma$  radiation nuclei
  - Relatively simple decay chain
  - Assumption: **Large impurity**



[Table5. Former radioactive nucleus on bioshield]

Nuclide	Half life (yr)	Radioactivity (Bq/g)	After shutdown (yr)			
			10	30	50	100
$^{51}\text{Cr}$	0.07	1.50E+02				
$^{54}\text{Mn}$	0.85	3.20E+02	4.20E-07			
$^{55}\text{Fe}$	2.737	5.10E+03	1.70E-03	9.90E-06	5.70E-08	
$^{59}\text{Fe}$	0.12	1.90E+02				
$^{58}\text{Co}$	0.19	1.60E+03				
$^{60}\text{Co}$	5.27	1.70E+04	2.00E-02	1.40E-03	1.00E-04	1.40E-07
$^{89}\text{Sr}$	0.14	2.60E+00				
$^{90}\text{Sr}$	28.79	9.30E+01	5.40E-04	3.40E-04	2.10E-04	6.30E-05
$^{90}\text{Y}$	0.007	9.30E+01	5.40E-04	3.40E-04	2.10E-04	6.30E-05
$^{95}\text{Zr}$	0.18	5.70E+01				
$^{95}\text{Nb}$	0.09	5.70E+01				
$^{129\text{m}}\text{Te}$	0.09	6.90E+01				
$^{131}\text{I}$	0.02	3.10E+03				
$^{134}\text{Cs}$	2	2.70E+04	4.10E-03	4.80E-06	5.40E-09	
$^{136}\text{Cs}$	0.04	2.50E+02				
$^{137}\text{Cs}$	30	1.70E-01	5.90E-01	3.70E-01	2.40E-01	7.40E-02

# Activation degree analysis

## Targeting major radioactive nuclide

### Radioactive decay with production (time dependence)

- $\frac{dn(t)}{dt} = \sigma * \phi * \text{capacity factor} - \lambda n(t)$
- rate of production - rate of loss
- $n(t)$ : number of nucleus on time t
- $\sigma$  : microscopic cross section
- $\phi$  : neutron flux
- *capacity factor* : 0.9 (40 year)
- $\lambda$ : decay constant ( $\frac{\ln 2}{\text{half life}}$ )
- $n(t) = \frac{R}{\lambda} (1 - e^{-\lambda t})$

[Table6. Assumed radioactive nucleus on bioshield]

Element	Weight Fraction	Weight (g)
H	0.006	13.8
C	0.175	402.4
O	0.41	942.75
Mg	0.033	75.88
Al	0.11	25.29
Si	0.035	80.48
K	0.001	2.3
Ca	0.321	738.11
Fe	0.008	18.4
Eu	2.94E-07	6.77E-04
Co	2.55E-06	5.86E-03
Total		2299.4
Density	2.2994 g/cc	


# Results and discussion

## Bioshield activation assessment

- Average cell neutron flux distribution (#/cm<sup>2</sup>sec)
  - Max: 4.62E+07
  - Min: 6.54E-45
  - Space: Non detected

[Table7. <sup>60</sup>Co neutron flux distribution ]

	291.5	344.5	397.5	450.5	503.5	Radius (cm)
1485-1375	2.62E-20	3.44E-26	2.39E-38	0.00E+00	0.00E+00	
1375-1255	3.98E-18	6.10E-22	8.39E-49	0.00E+00	0.00E+00	
1255-1135	1.72E-14	2.08E-14	0.00E+00	0.00E+00	0.00E+00	
1135-1015	3.15E+02	1.87E-16	0.00E+00	0.00E+00	0.00E+00	
1015-895	9.91E+00	5.33E-13	0.00E+00	7.60E-29	1.21E-24	
895-775	5.59E-07	6.48E-09	6.11E-23	2.98E-21	1.23E-16	
775-655	1.06E+02	4.12E+01	3.87E-16	7.38E-13	1.32E-12	
645-535	3.55E+03	2.04E+00	6.31E-11	2.84E-10	5.25E-10	
535-415	4.47E+03	8.65E+00	1.64E-07	1.60E-07	1.57E-07	
415-295	2.69E+04	1.92E+02	9.22E-06	3.94E-08	3.00E-08	
295-175	7.37E+03	1.90E+03	1.21E-04	2.22E-07	1.84E-07	
175-5	2.20E+03	4.38E+02	4.13E-03	6.34E-06	1.07E-07	
Height (cm)						



[Fig.6. Neutron flux distribution on Kori NPP unit 1]

# Results and discussion


## Bioshield activation assessment

### ■ $^{60}\text{Co}$ radioactivity distribution on Kori NPP Unit 1

- Max:  $7.11\text{E}+04$  Bq/g
- Min:  $1.01\text{E}-47$  Bq/g
- Space: Not detected

[Table8.  $^{60}\text{Co}$  radioactivity validation ]

Distance (cm)	Kori-1 (Bq/g)	Trojan (Bq/g)	Difference Ratio (Trojan/Kori-1)
291.5	4.E+03	7.E+03	2.E+00
344.5	2.E+02	8.E+01	4.E-01
397.5	4.E-04	1.E+00	3.E+03
450.5	6.E-07	2.E-01	4.E+05
503.5	4.E-08	1.E-03	3.E+04



[Fig7. Activation distribution on Kori NPP unit 1]

## Bioshield activation distribution analysis


### ■ Mesh average $^{60}\text{Co}$ Radioactivity on Bioshield region

- Clearance criteria

- KAERI/AR-800/2008  
[1Bq/g]: 70% volume

- Clearance value

- Radius range: 150cm  
(350cm - 500cm)
- Height range: 470cm  
(1015cm - 1485cm)
- **Radius < Height**



[Fig8. Kori NPP unit 1  $^{60}\text{Co}$  activation distribution]

# Conclusion


## Conclusion & Future plan

### ■ Conclusion

- $^{60}\text{Co}$  radioactivity distribution on Kori unit 1 Bioshield
  - Max:  $7.11\text{E}+04$  Bq/g
  - Min:  $1.01\text{E}-47$  Bq/g
  - Clearance volume: 70% (Further analysis required)

### ■ Future plan

- Multi nucleus decay system consideration
  - $^{152}\text{Eu}$  and  $^{154}\text{Eu}$
- Geometry specification
  - Reinforcing bar modeling (Fe)
  - Concrete type (impurity concentration)



[Fig9. Extra radionuclide assessment ex)]