



2.2 Experimental Results

Fig. 3 shows the temperature distributions of the penetration weld (PW1-PW4) and reactor vessel wall (RVH5-RVH11) for the test #1 and #3. As shown in Fig. 3(a) for the non-ERVC test (test #1), penetration weld was heated gradually and finally reached above the melting temperature (~ 1350 °C), which implies the penetration weld failure occurred. Large fluctuations in the late phase are due to the thermocouple failure after reaching the upper limit. On the other hand, the penetration weld and reactor vessel wall temperatures for the ERVC test (Fig. 3(b)) show lower values than those of non-ERVC test and remain below 500 °C for a long time. Then, PW1-PW4 increases sharply after about 3250 s. However, some penetration weld temperatures remain still below the melting temperature, which implies a partial melt of the penetration weld. Based on the ERVC water flow rate and temperature difference between inlet and outlet of water, the maximum removal heat flux by ERVC was evaluated at about 0.47 MW/m². Compressed air began to be supplied to pressurize the ICI nozzle up to 3.2 barg. The temperature measurement data for test #2 and test #4 are similar to those of test #1 and test #3 respectively.

Tube ejection failure did not take place for all the tests. The temperature measurement data are used for the development of ICI tube ejection failure model so called "PENTAP plus"[3, 4, 5].



(a) Non-ERVC condition



(b) ERVC condition

Fig. 3 Temperature distributions of the penetration weld and reactor vessel wall

Fig. 4 shows the photos of test specimens before and after the experiment. In the non-ERVC test, inside of the ICI nozzle was perfectly blocked before the test. Whereas, in the ERVC test, it was partially blocked at the bottom expecting some of the melt would flow inside the nozzle. The penetration weld and ICI nozzle above the inner reactor vessel wall are completely eroded for the non-ERVC tests (Fig. 4(a)). For the ERVC tests (Fig. 4(b)), the ICI nozzle above the inner reactor vessel wall is completely eroded but the penetration weld is partially eroded.




Fig. 4. Photos of test specimen before and after the experiment

3. Conclusions

Experimental analysis on ICI penetration tube ejection was conducted at the VESTA test facility with using a prototypic test specimen. ICI nozzle was compressed up to 3.2 barg during the test. Tube ejection failure did not take place under the test ranges. The penetration weld and reactor vessel wall temperatures were different between non-ERVC and ERVC conditions. The temperature measurement data along the nozzle wall and reactor vessel wall are very important for the development of penetration tube ejection model. They are used for the "PENTAP plus" code which can judge the failure of penetration tube ejection.

ACKNOWLEDGMENT

This work was supported by the National Research Foundation of Korea (NRF) grant funded by the Korea government (Ministry of Science and ICT; Grant No. 2017 M2A8A4015274).

REFERENCES

- [1] Kim, H.Y., An, S.M., Jung, J., Ha, K.S., Song, J.H., 2017. Corium Melt Researches at VESTA Test Facility, Nucl. Eng. Tech., 49, 1547-1554.
- [2] An, S.M. Jung, J., Kim, H.Y., 2015(a). Experimental Investigation on the APR1400 In-core Instrumentation Penetration Failure, Proceedings of Korean Nuclear Society Autumn Meeting, Gyeongju, Korea
- [3] Jung, J., An, S.M., Kim, H.Y., 2016. Numerical Simulation of the Penetration Tube Ejection Using PENTAP Plus, Proceedings of Korean Nuclear Society Spring Meeting, Jeju, Korea.
- [4] Rempe, J.L., Chavez, S.A., Thinnes, G.L., Allison, G.M., Korth, G.E., Witt, R.J., Sienicki, J.J., Wang, S.K., Stickler, L.A., Heath, C.H., Snow, S.D., 1993. Light Water Reactor Lower Head Failure Analysis, NUREG/CR-5642.
- [5] Villanueva, W., Tran C.T., Kudinov, P., 2012. Coupled Thermo-mechanical Creep Analysis for Boiling Water Reactor Pressure Vessel Lower Head, Nucl. Eng. Des. 249, 146-153.