

Coping Duration Assessment Using RG 1.155 Methodology on Shin-kori 5&6

Geehyu Park

KEPCO International Nuclear Graduate School

Contents

1. Introduction
2. Past and Present of SBO
 - 3.1 Station Blackout (SBO) & Cases
 - 3.2 improving Coping Method in Domestic NPP
4. Design Review in SKN 5&6
5. Coping Duration Calculation
 - 5.1 Determine the Off-site Power Design Characteristic Group
 - 5.2 Determine the Emergency AC Power Configuration
 - 5.3 Determine the EDG Reliability
 - 5.4 Determine the Coping Duration
6. Assumption
7. Conclusion

Introduction

① **WASH-1400** (1975) ■ SBO can cause severe damage to NPP

② **Unresolved Safety Issue** (A-44, 1980)

③ **SBO rule**
(10 CFR 50.63, 1988)



Station Black Out (RG 1.155, 1988)

■ Every light-water-cooled NPP should be able to maintain and recover from a SBO accident


NUMARC-8700

■ Calculate **coping duration** for 75 plants in U.S.


Introduction

◆ What is Coping Duration ?

SBO



※ In case of NPPs without HLO, Turbine Trip is not applicable



Time Difference

Restoration of Safety Switchgear from
Off-site AC Power

◆ What are we going to study?

- Typhoon Haishen and Maysak caused huge concerns to public about SBO accident
- In this study, using methodology provided in RG 1.155 (Station Blackout), we will calculate coping duration of Shin-kori 5&6 using latest weather and design condition
- Compare the result with current design basis (8 hours)
- Suggest 2 improvement points which can reduce coping duration

Past and Present of SBO

**After
Fukushima
Daiichi
Accident
(SBO)**

Risk Reduction

**Need for plant safety
evaluation considering SBO**

**Multi-unit SBO at the same
time**

**Coping method for long
term SBO**

**Trust from
Government/Public to NPP**

Mobile DG

**Increasing
Quality of
AACDG**


Past and Present of SBO

| Plant | Safety System | EDG/unit | AACDG |
|----------------------------|--------------------------------------|-----------------|---------------------------|
| Hannul 3&4 (OPR1000) | Mech. 2 division Elec. 2 division | 2 | 1/4 unit (Diesel) |
| Shin-kori 3&4 (APR1400) | Mech. 4 division Elec. 2 division | 2 | 1/2 unit (Diesel) |
| Shin-kori 5&6 (APR1400) | Mech. 4 division Elec. 2 division | 2 | 1/1 unit (Diesel) |
| EU-APR 1400 (APR+) | Mech. 4 division Elec. 4 division | 4 | 1/1 unit (Gas Turbine) |

IMPROVING


Design Review of SKN 5&6

Unit 5



Seismic Category I

Unit 6



Seismic Category I

Design Review of SKN 5&6



Coping Duration Calculation

◆ **Coping Duration (5 steps)**

① Off-site Power Determination

- Site susceptibility to grid-related loss of off-site power
- Estimated frequency of loss of off-site power due to Extremely Severe Weather (ESW)
- Estimated frequency of loss of off-site power due to Severe Weather (SW)
- Independence of off-site power system (I group)

② EAC power supply system configuration classification

③ EDG reliability

④ EDG target reliability determination

⑤ Coping Duration Determination

Coping Duration Calculation

◆ Off-site power design characteristic group determination (Step 1)

| Group | Contents |
|-----------|---|
| P1 | Sites characterized by redundant and independent power sources that are considered less susceptible to loss as a result of plant-centered and weather-initiated events. |
| P2 | Sites whose off-site power sources are less redundant or independent, or that are more susceptible to extended off-site power losses due to weather-initiated events or more frequent losses due to plant-centered events. |
| P3 | Sites whose off-site power sources are (1) least redundant or independent combined with moderate severe weather potential, (2) most susceptible to extended off-site power losses due to weather-initiated or grid-related events, or (3) susceptible to grid-related events. |

※ To determine off-site power design characteristic group, 4 steps needs to be analyzed.

- ① Site susceptibility to grid-related loss of off-site power
- ② Estimated frequency of loss of off-site power due to Extremely Severe Weather (ESW)
- ③ Estimated frequency of loss of off-site power due to Severe Weather (SW)
- ④ Independence of off-site power system (I group)

Coping Duration Calculation

◆ Off-site power design characteristic group determination (Step 1)

: Site susceptibility to grid-related loss of off-site power (Sub step 1)

- Analyze frequency of LOOP event caused by transmission and distribution system due to insufficient generating capacity, dynamic instability or excessive loads. (Grid failure caused by other reasons such as severe weather or brush fires are not considered)
- If loss of off-site power frequency caused by transmission and distribution system is higher than U.S. industry average ($20e^{-3}/\text{yr}$) off-site power design characteristic group belongs to P3

Coping Duration Calculation

LOOP accident in Korea since 1978

| Unit | Date | Initial event | Recovery Time |
|-----------------------------------|------------|-------------------|--------------------|
| Kori 3/4 | 1986.08.28 | Typhoon | 7 hours 45 minutes |
| Kori 1/2/3/4 | 1987.07.16 | Typhoon | 8 hours |
| Hanul 1/2 | 1997.01.01 | Heavy snow | 28 minutes |
| Kori 2 | 1998.09.27 | Equipment failure | 30 minutes |
| Wolsong 2 | 2004.06.19 | Human error | 3 hours 53 minutes |
| Hanbit 5 | 2006.11.29 | Equipment failure | 26 minutes |
| Wolsong 2 | 2009.09.03 | Human error | 1 hour 23 minutes |
| Hanbit 5 | 2010.12.29 | Human error | 21 minutes |
| Kori 3 | 2011.04.19 | Human error | 50 minutes |
| Kori 1 | 2012.02.09 | Human error | 12 minutes |
| Kori 3/4 Shin-kori 1/2 | 2020.09.03 | Typhoon | N/A* |

Operating year of NPPs in Kori/Saewool Site

| Unit | Commercial Operation Start | Operation Year |
|--------------------|----------------------------|----------------|
| Kori 1 | 1978.04.29 | 40 |
| Kori 2 | 1983.07.25 | 37 |
| Kori 3 | 1985.09.30 | 35 |
| Kori 4 | 1986.04.29 | 34 |
| Shin-kori 1 | 2011.02.28 | 9 |
| Shin-kori 2 | 2012.07.20 | 8 |
| Shin-kori 3 | 2016.12.20 | 4 |
| Shin-kori 4 | 2019.08.29 | 1 |
| Total | | 168 |

- Kori/Saewool site experienced 1 time since 1978
- Total operating year of NPPs in Kori/Saewool site is 168 year
- $1/168 = 5.6e-3/yr$ which is lower than U.S. industry average $20e-3/yr$

Coping Duration Calculation

◆ Off-site power design characteristic group determination (Step 1)

: Estimated frequency of loss of off-site power due to Extremely Severe Weather (Sub step 2)

- Extremely Severe Weather is defined as typhoon or tornado with wind velocity greater or equal to 125mph (201.2km/h or 55.9m/s)
- Since off-site power systems are not designed for this severe weather conditions, we would think the occurrence of these weather causes loss of off-site power.

Coping Duration Calculation

Maximum Wind Velocity (1937~2020)

| Name | Detected Area | Maximum Instantaneous Wind Velocity (m/s) | Date |
|------------------|---------------|---|------------|
| MAEMI | JEJU | 60 | 2003.09.12 |
| PRAPIROON | HUKSANDO | 58.3 | 2000.08.31 |
| RUSA | GOSAN | 56.7 | 2002.08.31 |
| CHABA | GOSAN | 56.5 | 2016.10.05 |
| NARI | GOSAN | 52 | 2007.09.16 |
| BOLAVAN | WANDO | 51.8 | 2012.08.28 |
| TED | ULLEUNGDO | 51 | 1992.09.25 |
| VERA | ULJIN | 49 | 1986.08.28 |
| NABI | ULLEUNGDO | 47.3 | 2005.09.07 |
| SARAH | JEJU | 46.9 | 1959.09.17 |

Extremely Severe Weather Group (ESW)

| ESW Group | ANNUAL WINDSPEED EXPECTATION ≥ 125 MPH |
|-----------|--|
| 1 | $e < 3.3 \cdot 10^{-4}$ |
| 2 | $3.3 \cdot 10^{-4} \leq e < 1 \cdot 10^{-3}$ |
| 3 | $1 \cdot 10^{-3} \leq e < 3.3 \cdot 10^{-3}$ |
| 4 | $3.3 \cdot 10^{-3} \leq e < 1 \cdot 10^{-2}$ |
| 5 | $1 \cdot 10^{-2} \leq e$ |

- Total 4 typhoon recorded instantaneous maximum wind velocity with more than 55.9m/s
- However, detected area is far and wind velocity reduced when it came near the Saewool site

Coping Duration Calculation

◆ Off-site power design characteristic group determination (Step 1)

: Estimated frequency of loss of off-site power due to Severe Weather (Sub step 3)

- 4 factors are used to calculate estimate frequency of loss of off-site power due to severe weather

① Annual expected snow fall around the site in inches (h1)

② Annual expected severe tornado at the site (h2)

③ Annual expected storms at the site with wind velocity between 75 and 124 mph
(120.7km/h~199.6km/h or 33.33m/s~55.44m/s) (h3)


④ Annual expected storms with significant salt spray for the site (h4)

- $f = (1.3 \times 10^{-4}) \times h1 + b \times h2 + (1.2 \times 10^{-2}) \times h3 + c \times h4$

Coping Duration Calculation

◆ **h1 calculation** : Annual expected snow fall around the site in inches

Annual average snow fall in Busan area (1966~2015)



- According to the 2nd Busan climate change adaptation plan reported by Busan Metropolitan City, annual average snow fall in Busan area is 4.3cm (1.69inch), **h1 = 1.69**

Coping Duration Calculation

◆ **h2 calculation** : Annual expected severe tornado at the site




- Tornado is a type of powerful wind with that occurs in the ground or sea which is a high-speed vortex
- Tornado vary in shape and size but are usually funnel-shaped, average 150~600m in diameter, and travel at a speed of 40~80km/h
- From the historical record, there are none of tornado creation is founded near the Saewool site
- For the conclusion, **h2 = 0**

Coping Duration Calculation

◆ **h3 calculation** : Annual expected storms at the site with wind velocity between 75 and 124 mph

- Factor h3 is expected frequency of typhoon with wind velocity between 75mph and 124mph (33.33m/s~55.44m/s)
- In this study, we used statistical data which is provided in Korea Meteorological Administration (KMA) website
- Maximum three 5° x 5° area is selected and system search every typhoon pass through those area

Coping Duration Calculation



Typhoon passed through two area I (1977~2020)

Typhoon passed through two area II (1977~2020)

- Unfortunately, target area (Saewool site) is located in boundary line. So we had to search in two options

Coping Duration Calculation

- Total 62 typhoon passed by these area since 1977
- 14 typhoon had wind velocity more than 33.3m/s near Saewool site
- HAESHEN (2020), MAYSAK(2020), CHABA(2016), GONI(2015),
SANBA(2012), SHANSHAN(2006), SONGDA(2004),
MAEMI(2003), RUSA(2002), ROBYN(1993), MIREILLE(1991),
CAITLIN(1991), DINAH(1987), THELMA(1987)
- $14/43\text{yr} = 0.3256/\text{yr}$, $\therefore h3 = 0.3256$

Coping Duration Calculation

◆ h4 calculation : Annual expected storms with significant salt spray for the site

- If typhoon with strong wind comes near the plant, salt spray must be affected to the off-site and uncovered on-site facilities
- We experienced impact of salt spray with typhoon MAYSACK(2020), HAISEHN(2020) and THELMA(1987)
- So, we made assumption that if typhoon with wind velocity more than 39m/s(Lowest among three typhoons) gives an impact of salt spray to Shin-kori 5&6

Coping Duration Calculation

- Total 7 typhoon record more than 39m/s of wind velocity when it reached near Saewool site since 1977
- HAISHEN(40m/s, 2020), MAYSAK(43m/s, 2020), SONGDA(41m/s, 2004), ROBYN(41m/s, 1993), MIRELLIE(46m/s, 1991), DINAH(44m/s, 1987), THELMA(39m/s, 1987)
- $7/43\text{yr} = 0.1627/\text{yr}$, $\therefore h_4 = 0.1627/\text{yr}$

Coping Duration Calculation

◆ Off-site power design characteristic group determination (Step 1)

: Estimated frequency of loss of off-site power due to Severe Weather (Sub step 3)

- For the conclusion, $h1=1.69$, $h2=0$, $h3=0.3256$, $h4=0.1627$

$$f=(1.3 \times 10^{-4}) \times \underline{1.69} + b \times \underline{0} + (1.2 \times 10^{-2}) \times \underline{0} + 0.78 \times \underline{0.1627} = \mathbf{0.1272}$$

※ According to NUMARC-8700, if certain plant determines it is susceptible to salt spray, $h3$ can be 0 because the impact of typhoon is considered in $h4$ calculation (which is way higher value)

| SW Group | ESTIMATED FREQUENCY OF LOSS OF OFFSITE POWER |
|----------|--|
| 1 | $f < 0.0033$ |
| 2 | $0.0033 \leq f < 0.01$ |
| 3 | $0.01 \leq f < 0.033$ |
| 4 | $0.033 \leq f < 0.1$ |
| 5 | $0.1 \leq f$ |

Coping Duration Calculation

◆ **Off-site power design characteristic group determination**

: Evaluate independence of off-site power system (Sub step 4)

- Classified in two groups, I1/2 and I3
- I1/2 group has independent and redundant AC source from off-site and more desirable transfer design
- I3 group has less desirable transfer design, simpler and more dependent in switchyard capabilities
- Shin-kori 5&6 has electrically and physically independent 765kV and 154kV system. Thus, Shin-kori 5&6 off-site power design belongs to

I1/2 group

Coping Duration Calculation

◆ Off-site power design characteristic group determination (Step 1)

- Shin-kori 5&6 off-site AC power design belong to P3 group according to the chart provided in R.G.1.155

Off-site power design characteristic group matrix (I1/2)

| SW Group | ESW Group | | | | | |
|----------|-----------|-----------|----|----|----|----|
| | | 1 | 2 | 3 | 4 | 5 |
| 1 | | P1 | P1 | P1 | P2 | P3 |
| 2 | | P1 | P1 | P2 | P2 | P3 |
| 3 | | P2 | P2 | P2 | P3 | P3 |
| 4 | | P3 | P3 | P3 | P3 | P3 |
| 5 | | P3 | P3 | P3 | P3 | P3 |

Coping Duration Calculation

◆ Emergency AC Power Configuration determination (Step 2)

| EAC Group | Shared and dedicated supplies for safe shutdown | Supplies available |
|-----------|---|--------------------|
| A | 1 | 3 dedicated |
| A | 1 | 4 |
| B | 2 | 5 |
| B | 2 | 4 |
| C | 1 | 2 dedicated |
| C | 1 | 3 shared |
| D | 3 | 4 |
| D | 3 | 5 |
| D | 2 | 3 |
| D | 1 | 2 shared |

- Shin-kori 5&6 design has 2 EDGs and 1 AACDG per each unit
- Only 1 EDG requires to energize safety class BUS for safe shutdown
- Shin-kori 5&6 belongs to **group C** in EAC group

Coping Duration Calculation

◆ EDG Reliability determination (Step 3 & 4)

- Average the number of failures in individual EDGs for the last 20, 50 and 100 demands
- If average is over 0.9 in 20 demands and 0.94 in 50 demands, the unit might select target reliability either 0.95 or 0.975
- If latest 20 demand do not meet 0.9 criteria, 0.95 reliability shall be selected
- For EDGs in Shin-kori 5&6 there is no start or failure record yet
- We will use EDG operation demand record from Shin-kori 1&2 (OPR 1000) and Shin-kori 3&4 (APR 1400) for last 5 years

Coping Duration Calculation

| Plant | EDG | Demand | Sucess | Fail (Date) | Reliability |
|--------------|-----|--------|--------|----------------------------|-------------|
| Shin-kori U1 | A | 88 | 87 | 1 (18.01.10) | 0.989 |
| | B | 83 | 81 | 2 (20.07.14) (17.02.07) | 0.976 |
| Shin-kori U2 | A | 96 | 94 | 2 (18.03.28) (17.09.19) | 0.979 |
| | B | 96 | 94 | 2 (15.03.11) (15.06.15) | 0.979 |
| Shin-kori U3 | A | 96 | 95 | 1 (15.11.11) | 0.99 |
| | B | 95 | 94 | 1 (18.11.13) | 0.989 |
| Shin-kori U4 | A | 49 | 49 | 0 | 1 |
| | B | 45 | 45 | 0 | 1 |

- Every EDGs in Shin-kori unit 1/2/3/4 has reliability more than **0.975**
- Since Shin-kori 5&6 has new design with new EDGs, we will assume target reliability of Shin-kori 5&6 EDG in 0.975

Coping Duration Calculation

◆ Coping Duration Determination (Step 5)

| Emergency AC Power Configuration Group | | | | | | | |
|--|--------------------|------|-------|------|-------|------|-------|
| Off-site Power Design Characteristic Group | A | | B | | C | D | |
| | Unit "Average" EDG | | | | | | |
| | 0.975 | 0.95 | 0.975 | 0.95 | 0.975 | 0.95 | 0.975 |
| P1 | 2 | 2 | 4 | 4 | 4 | 5 | 4 |
| P2 | 4 | 4 | 4 | 4 | 4 | 8 | 8 |
| P3 | 4 | 8 | 4 | 8 | 8 | 16 | 8 |

- Off-site power design characteristic group was P3
- Emergency AC power configuration group was C
- Target EDG reliability is 0.975
- For the conclusion, coping duration for Shin-kori 5&6 is 8 hours
(Current design applied 8 hours)

Improvement

◆ Protecting for salt spray

- If Shin-kori 5&6 design is protected from salt spray, h4 will be zero
- Off-site power loss frequency due to severe weather calculation will change

$$f=(1.3 \times 10^{-4}) \times 1.69 + b \times 0 + (1.2 \times 10^{-2}) \times 0.3256 + 0 \times 0.1395 = 0.004125$$

- SW group will be in group 2 and off-site power loss frequency characteristic group will be in P1

| | | ESW Group | | | | |
|----------|---|-----------|----|----|----|----|
| | | 1 | 2 | 3 | 4 | 5 |
| SW Group | 1 | P1 | P1 | P1 | P2 | P3 |
| | 2 | P1 | P1 | P2 | P2 | P3 |
| | 3 | P2 | P2 | P2 | P3 | P3 |
| | 4 | P3 | P3 | P3 | P3 | P3 |
| | 5 | P3 | P3 | P3 | P3 | P3 |

Improvement

◆ Protecting for salt spray

| Emergency AC Power Configuration Group | | | | | | | |
|--|--------------------|------|-------|------|-------|------|-------|
| Off-site Power Design Characteristic Group | A | | B | | C | D | |
| | Unit "Average" EDG | | | | | | |
| | 0.975 | 0.95 | 0.975 | 0.95 | 0.975 | 0.95 | 0.975 |
| P1 | 2 | 2 | 4 | 4 | 4 | 5 | 4 |
| P2 | 4 | 4 | 4 | 4 | 4 | 8 | 8 |
| P3 | 4 | 8 | 4 | 8 | 8 | 16 | 8 |

- If Shin-kori 5&6 design is protected from salt spray, coping duration will reduce to 4 hours and secure 4 hours of margin against SBO in current design

Improvement

◆ Including AACDG in EAC group

- AACDG in Shin-kori 5&6 has improved safety criteria and design than previous design
- If we include AACDG in EAC group, AACDG in each unit can be considered as Alternate AC power source to each other(By tie line)
- Then, Shin-kori 5&6 can be considered to have 3 EAC system with 1 requiring for safe shutdown

| EAC Group | Shared and dedicated supplies for safe shutdown | Supplies available |
|-----------|---|--------------------|
| A | 1 | 3 dedicated |
| A | 1 | 4 |
| B | 2 | 5 |
| B | 2 | 4 |
| C | 1 | 2 dedicated |
| C | 1 | 3 shared |
| D | 3 | 4 |
| D | 3 | 5 |
| D | 2 | 3 |
| D | 1 | 2 shared |

Improvement

◆ Including AACDG in EAC group

| Emergency AC Power Configuration Group | | | | | | | |
|--|--------------------|------|-------|------|-------|------|-------|
| Off-site Power Design Characteristic Group | A | | B | | C | | D |
| | Unit "Average" EDG | | | | | | |
| | 0.975 | 0.95 | 0.975 | 0.95 | 0.975 | 0.95 | 0.975 |
| P1 | 2 | 2 | 4 | 4 | 4 | 5 | 4 |
| P2 | 4 | 4 | 4 | 4 | 4 | 8 | 8 |
| P3 | 4 | 8 | 4 | 8 | 8 | 16 | 8 |

- If we consider AACDG to be included in EAC group, coping duration of Shin-kori 5&6 will be 4 hours and secure 4 hours of margin against SBO in current design

Conclusion

- SKN 5&6 is designed based on coping duration 8 hours and calculated in 4 hours (PSAR)
- In this report, coping duration of SKN 5&6 is calculated in 8 hours
- Main difference between current design document (PSAR) and this study is applying effectiveness of salt spray



Conclusion

- And weather and design approach we applied in this study was very conservative and harsh
- Coping duration methodology provided in RG 1.155 is not sufficiently considered for domestic NPPs
- Further research and investigation is necessary to develop coping duration calculation for domestic NPPs

Conclusion

- Due to the global warming, maximum wind speed and maximum instantaneous wind speed increased rapidly
- Also, speed and size of typhoon is predicted to increase in Korea peninsula
- For the future safety against SBO, developing facilities against salt spray and improving quality of AACDG seems necessary

Maximum Wind Speed change (1904~2012)



Thank you