

Analysis of Heat Removal Strategy during Reactor Coolant Pump Seal Failure

Ji-Hwan Cha

Physical Protection Division,

Korea Institute of Nuclear Nonproliferation and Control, 1418 Yuseong-daero, Yuseong-Gu, Daejeon, 34101, Republic of Korea
jh_cha@kinac.re.kr



I. Introduction

● Research Purpose

- Most of the initial events that may be caused by sabotage attacks could be prevented by secondary heat removal strategy operations.
- However, in the event of a power outage such as Station Black Out (SBO), loss of primary Component Cooling Water (CCW), or loss of primary Essential Service Water (ESW), cooling of the thermal barrier of the reactor coolant pump and injection of sealing water are simultaneously lost, resulting in damage to the seal of the reactor coolant pump.
- In this case, in order to prevent the core damage, heat removal strategy on the primary system must be performed in addition to heat removal strategy on the secondary system.
- However, in the case of Westinghouse type plants such as Kori Units 3, 4, since only the secondary heat removal strategy was adopted, the feasibility was analyzed in this study, and as a result, it was confirmed that sufficient time can be secured to damage the core even in the situation of damage to the reactor coolant pump seal..

Time after loss of seal cooling (min)	0-13	13-120	120-
Gpm / RCP (probability)	21(10)	21(0.79)	21(0.79)
Gpm / RCP (probability)	-	76(0.01)	76(0.01)
Gpm / RCP (probability)	-	182(0.1975)	182(0.1975)
Gpm / RCP (probability)	-	480(0.0025)	480(0.0025)

▲ Leakage (gpm) per reactor coolant pump according to the elapsed time after loss of all sealed cooling

● Core Damage Frequency Analysis

- The probabilistic analysis was conducted through the thermohydrodynamic analysis and scenario analysis for the core damage frequency and the spare time until the core damage due to the nuclear reactor coolant pump sealing damage.
- As a result, even if the operation of the turbine-driven auxiliary water supply pump (TDAFWP) is secured only, which is the secondary system heat removal strategy without the operation of the reactor coolant cooldown (RCS C/D), the core exposure time is 20.4 hours when the case 1 event occurs.

Scenario	RCP leakage units		Loss of RCS inventory (gpm)	Pressurizer water level loss time (hrs)	Core exposure time (hrs)	
	21 gpm	182 gpm			with RCS C/D	with TDAFW only
Case1	3	0	63	115	208	204
Case2	2	1	224	105	197	182
Case3	1	2	385	095	185	81
Case4	0	3	546	085	171	52

▲ Analysis of core exposure time according to reactor coolant pump leakage

II. Analysis of Heat Removal Strategy

● Leakage Rate Analysis

- In order to reduce the possibility of damage to the reactor coolant pump seal caused by injection of sealed water and loss of CCW, the Westinghouse type plants sealing was replaced with an O-ring that could withstand high temperatures.
- The event tree of the nuclear reactor coolant pump seal failure consists of two events: popping opening and binding failure.
- Through these two events, the probability of sealing failure was analyzed. According to the Westinghouse Non-proprietary Class 3 Technical Analysis Report (WCAP-15603, Rev.1-A), the leakage of the reactor coolant pump was analyzed probabilistically after the loss of sealed cooling.
- As each sealed cooling is lost and the elapsed time elapses from 0 to 13 mins, 13 mins to 120 mins, and more than 120 mins, respectively, the leakage amount of the reactor coolant pump is determined from 21 gpm to 480 gpm according to the probability of occurrence per elapsed time..

III. Conclusion

● Analysis of Heat Removal Strategy during RCP failure

- In this study, analysis of heat removal strategy during reactor coolant pump seal failure was performed by leakage rate and core damage frequency analyses.
- Consequently, only the secondary heat removal strategy was adopted without primary heat removal strategy, it was confirmed that sufficient time can be secured to damage the core even in the situation of damage to the reactor coolant pump seal.

