

SPACE analysis of loss of SI injection concurrent with SBLOCA for SMART-ITL

Jong Hyuk Lee^{a*}, Sung Won Bae^a, Kyung-doo Kim^a
^aKorea Atomic Energy Research Institute, Yuseong-gu, Daejeon, 34057, Rep. of Korea

*Corresponding author: leejonghyuk@kaeri.re.kr

Background and Objective

- ❑ The PIRT for SMART100-DECs has been developed to identify the T-H phenomena that could happen during the DECes without core melting of SMART100.
- ❑ Based on the PIRT, we also derive the improvement or validation items for T-H model of the SPACE.
- ❑ In this regard, T-H models of the SPACE has been improved to simulate the SMART applications.

Objectives of this paper

To validate the capability of the SPACE for SMART applications, SMART-ITL F102 test for SBLOCA concurrent with partially passive safety injection fail was selected.

SMART-ITL F102 test

Scenario

- SBLOCA initiates by the break at SI line.
- RCS pressure begins to decrease and a reactor trip signal is generated by Low PZR pressure.
- Although CMTAS and PRHRS were generated, all the CMTs and PRHRS are assumed to be failed.
- When RCS pressure reaches to the SITAS set-point, only SITs are injected into the SI line.

Sequence of Events

| Event | Setpoint |
|-------------------------------|---|
| Initiation of Break | - |
| Generation of RCS trip signal | LPP+1.1 s |
| - Turbine trip | |
| - RCP coastdown | |
| - FW stop | |
| - CMTAS | |
| Control Rod Injection | LPP+1.6 s |
| PRHRAS | LPP+5.2 s |
| MSIV / FIV close | PRHRAS+5.0 s |
| SITAS | $P_{PZR} = 2 \text{ MPa} + 1.1 \text{ s}$ |
| SIT injection | SITAS+1.1 s |
| Test Ended | |

Conclusions

- ❑ The SPACE calculation for major parameters show reasonable agreements with the SMART-ITL test.
- ❑ The improve T-H model of the SPACE for SMART applications well implemented and we can conclude that the SPACE can be utilized for SMART applications.
- ❑ As a further work, we will conduct the sensitivity study for the break flow to more accurately predict the behavior of SBLOCA in the SMART-ITL test.

Steady-state condition

| | EXP | SPACE | Diff(%) |
|-------------------------------|--------|--------|----------|
| Initial Core Power (kW) | 1,711 | 1,711 | BC |
| Core inlet & Outlet (K) | 568.55 | 568.30 | -0.043 |
| | 594.75 | 594.17 | -0.098 |
| SG primary Inlet & Outlet (K) | 594.95 | 593.96 | -0.166 |
| | 571.45 | 570.00 | -0.253 |
| RCS flow rate (kg/s) | 11.525 | 11.52 | adjusted |
| Pressure (MPa) | 15 | 15 | BC |
| PZR temp (K) | 613.15 | 615.25 | 0.342 |
| PZR water level (m) | 3.115 | 3.074 | -1.316 |
| SG sec. Inlet & Outlet (K) | 502.85 | 502.86 | BC |
| | 590.15 | 593.93 | 0.639 |
| SG flow rate (kg/s) | 0.784 | 0.784 | BC |
| FW Pressure (MPa) | 5.72 | 5.72 | BC |
| MS Pressure (MPa) | 5.63 | 5.69 | 1.066 |

Transient results

