


A Study on Effect of Assembly Power History to Gamma Dose Rate in Spent Fuel Pool at a Short Cooling Time

Yunki Jo, Deokjung Lee*

Department of Nuclear Engineering, Ulsan National Institute of Science and Technology, 50 UNIST-gil, Ulsan, 44919, Republic of Korea



yunki.jo@unist.ac.kr, deokjung@unist.ac.kr




23S-706

Introduction



- The radiation dose rate on the water surface of spent fuel pool must be less than $25 \mu\text{Sv/hr}$ according to ANSI/ANS 57.1-1992.
- The radiation source terms of spent fuel can be affected by many parameters such as fuel enrichment, assembly burnup, power history, cooling time, etc.
- In this study, tendency of radiation source terms depending on burnup and power history is observed at a short cooling time of 100 hours to consider a refueling situation.

Codes, Methods & Models

- A deterministic neutron transport code using Method of Characteristics, STREAM is used to calculate radiation source term. It is also used in depletion calculation of 2-D fuel assembly.
- It has a capability to compute radioactivity, decay heat, neutron and gamma source spectra for spent nuclear fuel.
- A Monte Carlo particle transport code MCS is used to 3-D whole core depletion calculation and gamma dose rate calculation in spent fuel pool.
- A weight window (WW) variance reduction technique is used in the gamma dose rate calculation.
- Calculation procedure for dose rate calculation in spent fuel pool.




- Hypothetical OPR-1000 whole core model by MCS




Radiation Source Term Calculation for 2-D Fuel Assembly

- STREAM is used to depletion & source term calculations for PLUS7 fuel assembly.
- Case 1) Different assembly burnup with the same power density. Power density = 36.85 W/g up to each target burnup (60, 55, 50, 45, 40 MWd/kgU).



- Case 2) Same assembly burnup with different power history. Power density = 36.85 W/g (0-40 MWd/kgU) → 120, 100, 80, 60, 40% of 36.85 W/g (40-60 MWd/kgU)



Radiation Source Term Calculation for 3-D Core Model

- Assembly-wise burnup and normalized power distribution at end of cycle.

	H	J	K	L	M	N	P	R		H	J	K	L	M	N	P	R
1	49.1	46.5	47.7						FA-wise Burnup @ EOC (MWd/kgU)	0.48	0.48	0.39					
2	20.8	20.9	20.2	15.7	47.8					1.21	1.21	1.14	0.90	0.39			
3	43.3	40.7	23.5	52.5	17.2	49.4				1.07	1.14	1.30	0.88	1.02	0.44		
4	44.6	24.2	44.5	36.6	21.9	17.2	47.8			1.09	1.33	1.05	1.11	1.25	1.02	0.39	
5	23.9	44.0	38.9	42.6	36.6	52.5	15.7			1.32	1.08	1.12	1.05	1.11	0.88	0.90	
6	43.4	41.8	23.7	38.9	44.5	23.5	20.2	47.7		1.04	1.10	1.32	1.11	1.05	1.30	1.14	0.39
7	41.0	23.0	41.8	44.0	24.2	40.7	20.9	46.5		1.07	1.30	1.10	1.08	1.33	1.14	1.21	0.48
8	33.8	41.0	43.4	23.9	44.6	43.3	20.8	49.1		0.85	1.07	1.04	1.32	1.09	1.07	1.21	0.48

- Assembly-wise radiation source distribution at cooling time of 100 hours.

- Neutron source highly depends on burnup dist. & Gamma source highly depends on power dist.

	H	J	K	L	M	N	P	R		H	J	K	L	M	N	P	R
1	6.61	5.38	5.70						Neutron source (1E+08/sec)	2.98	2.95	2.46					
2	0.36	0.37	0.33	0.15	5.84				Tcool = 100 hrs	6.38	6.37	5.99	4.60	2.44			
3	4.78	3.85	0.53	8.42	0.20	6.71				6.28	6.60	6.95	5.32	5.24	2.72		
4	5.25	0.60	5.19	2.50	0.43	0.20	5.84			6.47	7.15	6.23	6.27	6.56	5.24	2.44	
5	0.57	4.97	3.16	4.38	2.50	8.41	0.15			7.08	6.36	6.40	6.13	6.27	5.32	4.59	
6	4.87	4.15	0.57	3.16	5.19	0.53	0.33	5.70		6.12	6.38	7.04	6.40	6.23	6.95	5.98	2.46
7	3.90	0.50	4.15	4.97	0.60	3.85	0.37	5.38		6.17	6.92	6.38	6.36	7.15	6.60	6.38	2.95
8	5.27	3.90	4.87	0.57	5.25	4.78	0.36	6.61		5.16	6.17	6.12	7.08	6.47	6.28	6.38	2.98


- Assembly-wise radiation source distribution at cooling time of 20 years.

- Both neutron & gamma sources highly depend on burnup distribution.

	H	J	K	L	M	N	P	R		H	J	K	L	M	N	P	R
1	2.16	1.67	1.88						Neutron source (1E+08/sec)	3.10	2.96	3.03					
2	0.06	0.06	0.05	0.02	1.93				Tcool = 20 years	1.45	1.46	1.41	1.11	3.02			
3	1.35	1.04	0.10	2.70	0.03	2.23				2.82	2.69	1.62	3.34	1.21	3.09		
4	1.53	0.11	1.51	0.60	0.07	0.03	1.93			2.89	1.66	2.88	2.45	1.52	1.21	3.02	
5	0.11	1.43	0.82	1.23	0.60	2.70	0.02			1.64	2.87	2.58	2.77	2.45	3.34	1.11	
6	1.38	1.14	0.11	0.82	1.51	0.10	0.05	1.88		2.81	2.75	1.63	2.58	2.88	1.62	1.41	3.03
7	1.04	0.09	1.14	1.43	0.11	1.04	0.06	1.67		2.70	1.59	2.75	2.87	1.66	2.69	1.46	2.96
8	1.60	1.04	1.38	0.11	1.53	1.35	0.06	2.16		2.10	2.70	2.81	1.64	2.89	2.82	1.45	3.10

- Axial power distribution at end of cycle (left) and Gamma source distribution at cooling time of 100 hours (center) & 20 years (right).

- At a short cooling time, the gamma source emission is largely affected by short-lived nuclides in fission products. After few years cooling period, it is mostly affected by long-lived fission products such as Cs-137 ($T_{1/2} = 30.1$ years)



Dose Rate Calculation in Spent Fuel Pool



- Gamma source only from the assembly in transit is considered in dose rate calculation. The contribution by gamma from FAs stored at bottom of spent fuel pool are negligible.

- Axial gamma source distribution of selected FAs at cooling time of 100 hours.

- Gamma source spectrum of selected FAs at cooling time of 100 hours.
 - About 68% of gamma sources are emitted below 450 keV.
 - Most of low energy photons are caused by Np-239 ($T_{1/2} = 2.36$ d), which is produced in a transmutation process from U-238 to Pu-239
 - Spectrum peak at 450-500 keV: Ru-103 ($T_{1/2} = 39.2$ d) and La-140 ($T_{1/2} = 1.68$ d)
 - Spectrum peak at 700-800 keV: Nb-95 ($T_{1/2} = 35$ d) and Zr-95 ($T_{1/2} = 64$ d)


↓ Table: Effect of weight window method in dose rate calculation

Loc.(cm)	Analog (16.3 hours)	WW (6.89 hours)	FOM ratio
84.38	$4.6\text{E-}9 \pm 0.5\%$	74026	$4.5\text{E-}9 \pm 0.09\%$
134.38	$1.7\text{E-}10 \pm 3\%$	2533	$1.7\text{E-}10 \pm 0.1\%$
184.38	$8.9\text{E-}12 \pm 13\%$	119	$8.7\text{E-}12 \pm 0.2\%$
209.38	$1.9\text{E-}12 \pm 33\%$	19	$2.1\text{E-}12 \pm 0.3\%$



$$\rightarrow \text{FOM} = \frac{1}{T\sigma^2}$$

- Dose rate of selected FAs (ICRP-116 is used as a photon flux-to-dose conversion factor)
 - The light purple region between M07 & P04 represents available gamma dose rates.
 - Dose rate from K08* is ~1.6 times higher than the one from K08. It is much higher than the one from M07 which has ~1.25 times bigger gamma source intensity.



Conclusion

- At a short cooling period, it is observed that neutron source intensity highly depends on burnup and gamma source intensity highly depends on power history.
- Therefore, not only assembly burnup, but also assembly power history should be carefully considered for the source term and dose rate calculations at a short cooling time such as a refueling period.