



that might lead to more severe accidents, such as coolant boiling, fuel melting, cladding failure and loss of structural integrity.

In order to account for uncertainties, a total of 40 cents during 15 seconds is adopted as the UTOP initiator, which represents withdrawal of some banks of the primary control rods. The reactor powers for the 600MWe, 1200MWe and 1800MWe reactors reach peaks of about 1.4 times the rated power at approximately 30 seconds and then slowly decreases to seek equilibrium with the available heat sink provided by the coolant system heat capacity and the heat rejection by the SGs. The powers begin to level off at about 1.1 times the rated power by 1000 seconds. The UTOP event results in no fuel failures and no sodium boiling. The self-regulation of power without scram is mainly due to the inherent and passive reactivity feedback.

The ULOF accident is assumed to initiate at the full-power condition. The transient is initiated by all primary pumps trip at 0.0 seconds and following coast down. The power immediately begins to drop and then slowly decreases to seek equilibrium with the available heat sink provided by the coolant system heat capacity and the heat rejection by the SGs. The rapid increase of the fuel temperatures in the early phase of the transient is attributed to the power-to-flow mismatch, and subsequent gradual drops of those temperatures result from the negative feedback effects. The maximum cladding temperatures predicted by SSC-K are below the threshold for eutectic formation; however they potentially threaten the integrity of the cladding.

The ULOHS accident is assumed to start with loss of heat rejection capability at all of the SGs, with PHTS and IHTS pumps continuing to run. The rapid slightly increase of the fuel temperature in the early phase of the transient is attributed to the degraded heat removal through the IHXs. The fuel temperatures ultimately reach a quasi-equilibrium condition as the core heat generation rate is balanced with the heat removal rate by the PDRC. The reactor heat is transported to the heat capacity provided by the PHTS and IHTS coolant inventory, and it is also rejected by the PDRC. The long term cooling calculation begins at a certain time using the plant conditions taken from the SSC-K results. The long-term cooling analysis proves that the PDRC heat removal capacity is sufficient to cool down the plant without jeopardizing the structural integrity of the PHTS within the desired 72 hours.

The summaries of peak temperatures of the safety criteria predicted by SSC-K are presented in Figs 3 through 5. Under both the UTOP and ULOHS accident conditions, the proposed designs provide sufficient safety margins for the criteria of fuel melting (1070°C), cladding failure, loss of structural integrity and sodium boiling. However, in the case of the ULOF accident, the predicted cladding temperatures, for the three proposed reactor designs, are all slightly higher than the lower temperature limitation during relatively short periods.

However, no cladding damage is expected during the ULOF accident.




Fig.3 Peak Temperatures for 600MWe Burner Reactor




Fig.4 Peak Temperatures for 1200MWe Burner Reactor




Fig.5 Peak Temperatures for 1800MWe Burner Reactor

#### 4. Conclusion

It is shown that the proposed burner reactor designs have inherent safety characteristics and are capable of accommodating the ATWS events. The inherent safety mechanism in the reactor designs makes the core shutdown with sufficient margin and the passive removal of decay heat with matching the power to heat sink by passive self-regulation. The self-regulation of power without scram is mainly due to the inherent and passive reactivity feedback in conjunction with the large thermal inertia of the PHTS, extended pump coast down characteristics, and reliable PDRC heat capacity.

#### REFERENCES

- [1] Y. I. KIM et al., "Core Design Study of Sodium-Cooled Fast Reactor for TRU Transmutation." KAERI/RR-3063/2009.
- [2] Y. M. Kwon et al., "SSC-K Code Users Manual, Rev.1," KAERI/TR-2014/2002.