

Seismic Adequacy Verification of Safe Shutdown Equipment in Wolsong Unit 1

Kwang-Ho Joo

PSR Assessment Team, NETEC, Korea Hydro and Nuclear Power Co., jookh@khnp.co.kr

1. Introduction

Wolsong unit 1 is a nuclear power plant designed and qualified by codes and standards set before the establishment of seismic qualification technology in 1975 [1], and as such has inherently some seismic issues. The U.S. has defined similar nuclear power plants to Wolsong unit 1 as USI (Unresolved Safety Issue) A-46 plants and has resolved the seismic issues of the plants according to the Generic Implementation Procedure (GIP) developed by the Seismic Qualification Utility Group (SQUG) for the seismic adequacy verification of safe shutdown equipment in the plants. Wolsong unit 1 also needed to verify the seismic adequacy of safe shutdown equipment for continued operation. The aim of this paper is to present the verification process of the seismic adequacy of Wolsong unit 1 through the application of the SQUG GIP methodology and the performance of seismic walkdown as a CANDU (CANadian Deuterium Uranium)-type reactor for the first time in Korea. After all, it is to ensure the seismic safety until the next periodic safety review after the designed lifetime [2].

2. Methods and Results

2.1 Scope

To prepare a list of equipment subject to seismic adequacy verification in Wolsong unit 1, the safe shutdown equipment list was derived by selecting system and equipment on the safe shutdown path guaranteeing the following four essential safe shutdown functions with the SQUG GIP guide.

- Reactor Reactivity Control
- Reactor Coolant Pressure Control
- Reactor Coolant Inventory Control
- Decay Heat Removal

2.2 Criteria

This verification has confirmed applicable the codes to Wolsong unit 1 according to the Atomic Energy Law article 23.3 'Periodic safety review', and the Enforcement decree of the above law article 42.3 'Factors of periodic safety review' and has applied these laws and codes as the verification criteria.

- Bulletin No. 2008-7 by Ministry of Education, Science and Technology, 'Criteria related to location of nuclear power plant facilities'.

- Bulletin No. 2008-13 by Ministry of Education, Science and Technology, 'Regulations on safety classification and grade of nuclear power plant facilities'.
- Seismic Qualification Utility Group, Generic Implementation Procedure for Seismic Verification of Nuclear Power Plants Equipment, Revision 3A, December 2001.

2.3 Methods

To check the physical installation status and the functionality of the equipment on the safety shutdown path in Wolsong unit 1, the walkdown was carried out about whether the equipment had seismic adequacy according to the screening walkdown plan requested in appendix F of SQUG GIP.

The number of equipment with safe shutdown functions subject to the walkdown was 396. Screening evaluation work sheets were prepared for individual equipment and the relevant walkdown results were recorded on the sheets to verify the seismic adequacy (refer to Table I).

Table I: Sample of screening evaluation work sheet for Emergency Diesel Generator.

Screening Status:	Screened Out	Wolsong NIPP	Revision 3A
Unit No.:	1	SCREENING EVALUATION WORK SHEET (SEWS)	
Equipment ID No.:	EG20-001	Equip. Class:	17 - Engine-Generators
Equipment Description:	Emergency DG		
Location: Bldg:	RPS Building	Floor/EI:	100
		Room, Row/Col:	8170
Manufacturer:	Waukesha Engine Division Dresser Industry	Model:	L6870C-D8U
SEISMIC CAPACITY VS DEMAND			
1. Elevation where equipment receives seismic input:			100
2. Elevation of seismic input below about 40' from grade:			Yes
3. Equipment has fundamental frequency above about 8 Hz:			Unknown
4. Capacity based on:	<input type="radio"/> Existing Documentation <input checked="" type="radio"/> Bounding Spectrum <input type="radio"/> 1.5 X Bounding Spectrum <input type="radio"/> GERS		
5. Demand based on:	<input type="radio"/> Ground Response Spectrum <input type="radio"/> 1.5 X Ground Response Spectrum <input checked="" type="radio"/> Conserv. Des. In-Str. Resp. Spec. <input type="radio"/> Resonant In-Str. Resp. Spec.		
Does capacity exceed demand? (Indicate at right (*) and in Comments if a special exception to enveloping of seismic demand spectrum is invoked per Sect. 4.2 of the GIP)			Yes*
CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)			
1. Equipment is included in the earthquake experience equipment class			Yes
2. Other and driven equipment connected by a rigid support or common skid			Yes
3. Base vibration isolators adequate for seismic loads			Yes*
4. Attached lines (cooling, air, electrical) have adequate flexibility			Yes
5. Anchorage adequate (See checklist below for details)			Yes
6. Relays mounted on equipment evaluated			N/A
7. Have you looked for and found no other adverse concerns?			Yes
Is the intent of all the caveats met for Bounding Spectrum?			Yes

2.4 Results

According to the walkdown, most equipment were satisfied with all criteria of excitation force for earthquakes, criteria of database for earthquakes, criteria of anchorage for equipment support, and criteria of mutual interference between equipment, and the

seismic adequacy was verified. However, items of 75 equipment were classified as outliers they didn't meet one or more of the evaluation criteria [3, 4].

The walkdown results of the installation status of the equipment and seismic adequacy verification were summarized in screening verification data sheets (refer to Table II).

Table II: Sample of screening verification data sheet.

Screening Verification Data Sheet (SVDS)											
Equipment Class	Equipment ID	Equipment Description	BLDG	Floor/EI (ft)	Room Row/Col	C/D	BS Category	Anchor	SI	Screened?	
00 - Generic Input Form	3432-STR1	ECCS Water Strainer	RB	Basemat	R009	Yes	NA	Uln	Yes	No	
00 - Generic Input Form	3432-STR2	ECCS Water Strainer	RB	Basemat	R009	Yes	NA	Uln	Yes	No	
00 - Generic Input Form	5290-Silencer1	DG Silencer	EPS	106.4	ROOF	Yes	NA	Yes	Yes	Yes	
00 - Generic Input Form	5290-Silencer2	DG Silencer	EPS	106.4	ROOF	Yes	NA	Yes	Yes	Yes	
01 - Motor Control Centers	5290-MCC40	ECCS MOV Control	SCA	95.43	S028	Yes	Yes	Yes	Yes	Yes	
01 - Motor Control Centers	5290-MCC41	ECCS MOV Control	SCA	95.43	S028	Yes	Yes	Yes	Yes	Yes	
01 - Motor Control Centers	5290-PLB9-MCC	480VAC EPS MCC	SCA	95.43	S014	Yes	N/A	N/A	Yes	Yes	

CERTIFICATION:
 All the information contained on this Screening Verification Data Sheet (SVDS) is, to the best of our knowledge and belief, correct and accurate. "All information" includes each entry and encompasses whether verified to be necessarily accurate or not.

APPROVED: (Signatures of all Seismic Capability Engineers on the Seismic Review Team (SRT) are required, there should be at least two on the SRT. All signatures should appear with all of the entries and corrections. One signature should be a licensed professional engineer.)

CERTIFICATION:
 The information provided to the Seismic Capability Engineers regarding systems and operations of the equipment contained on this SVDS is, to the best of our knowledge and belief, correct and accurate.

APPROVED: (One signature of Systems or Operations Engineer is required if the Seismic Capability Engineers deem it necessary.)

The detailed review was performed regarding inappropriate equipment classified as outliers according to the walkdown and evaluation. Seismic demand reduction was realized through detailed reanalyses of individual equipment. Reinforced design of anchorages of individual equipment was applied to resolve the issues and examples showing such reinforcement are presented in Figures 1 and 2.

3. Conclusions

This paper presented the verification process of the seismic adequacy of the safe shutdown equipment in Wolsong unit 1 and then the seismic issues of the plant were resolved through SUG GIP to satisfy the legal requirements required by the Atomic Energy Law as a CANDU-type reactor for the first time in Korea.

Now some follow-up measures are being conducted on equipment requiring reinforcement as a result of this seismic adequacy verification at the plant. When the follow-up measures are completed by the end of 2010, the seismic adequacy will be guaranteed enough more than at the moment for all the equipment in Wolsong unit 1.

REFERENCES

- [1] IEEE Standard 344, IEEE Recommended Practices for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations, 1971.
- [2] Seismic Qualification Utility Group, Generic Implementation Procedure (GIP) for Seismic Verification of Nuclear Power Plants Equipment, Revision 3A, December 2001.
- [3] CSA CAN3-N289.4-M86, Testing Procedures for Seismic Qualification of CANDU Nuclear Power Plants.
- [4] Gleason, J.F., EPRI NP-5024, Seismic Ruggedness of Aged Electrical Components, EPRI, January 1987.




Fig. 1. Example of reinforced emergency diesel generator supports.




Fig. 2. Example of reinforced masonry wall.